

... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : Clark Insurance fitness room #1
Drawing : FP-01
Location : 1945 Congress Street
Remote Area : #1
Contract :
Data File : Fitness Room 1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Clark Insurance fitness room
Location: 1945 Congress Street
Drawing no: FP-01
Date: 8/14/17

Design

Remote area number: #1
Remote area location: Fitness Room
Occupancy classification: Light Hazard
Density: .1 - Gpm/SqFt
Area of application: 5-head spec - SqFt
Coverage per sprinkler: 324 - SqFt
Type of sprinklers calculated: extended coverage pendants
No. of sprinklers calculated: 5
In-rack demand: n/a - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 270 - GPM @ 74 - Psi
Type of system: Wet System
Volume of dry or preaction system: n/a - Gal

Water supply information

Date: 8-11-17
Location: Corner of Congress St and International Parkway
Source: Portland Water District

Name of contractor: HIGH TECH FIRE PROTECTION
Address: 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Clark Insurance fitness room #1

Page 2
Date 8/18/17

City Water Supply:
C1 - Static Pressure : 85
C2 - Residual Pressure: 80
C2 - Residual Flow : 1378

Demand:
D1 - Elevation : -1.299
D2 - System Flow : 169.416
D2 - System Pressure : 73.496
Hose (Demand) : 100
D3 - System Demand : 269.416
Safety Margin : 11.259



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Clark Insurance fitness room #1

Page 3
Date 8/18/17

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Clark Insurance fitness room #1

Page 4
Date 8/18/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	8	16.6	na	32.59	0.1	324	16.6
100	10.0	K = K @ EQ01	31.26	na	32.59			
101	10.0	K = K @ EQ01	31.78	na	32.86			
102	10.0	K = K @ EQ01	33.65	na	33.82			
110	10.0	K = K @ EQ01	35.9	na	34.93			
111	10.0	K = K @ EQ01	36.49	na	35.21			
112	10.0		38.62	na				
AA	10.0		43.41	na				
AB	10.0		43.75	na				
AC	10.0		45.42	na				
AD	12.0		45.16	na				
AE	12.0		45.84	na				
AF	10.0		47.31	na				
AG	10.0		48.67	na				
AH	10.0		55.57	na				
AI	10.0		61.14	na				
TOR	10.0		64.18	na				
FLW	5.0		69.73	na				
BOR	0.0		78.67	na				
H1	0.0		78.91	na				
H2	0.0		78.95	na				
H3	0.0		78.96	na	100.0			
TEST	13.0		73.5	na				

The maximum velocity is 14.33 and it occurs in the pipe between nodes 102 and AA

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Clark Insurance fitness room #1

Page 5
Date 8/18/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	32.59 32.59	1.049 120.0 0.3212	2T	10.0 0.0 0.0	37.000 10.000 47.000	16.600 -0.433 15.097			K Factor = 8.00 Vel = 12.10	
	0.0 32.59						31.264		K Factor = 5.83	
100 to 101	32.59	1.682 120.0 0.0322		0.0 0.0 0.0	16.000 0.0 16.000	31.264 0.0 0.516			K Factor @ node EQ01 Vel = 4.71	
101 to 102	32.87 65.46	1.682 120.0 0.1170		0.0 0.0 0.0	16.000 0.0 16.000	31.780 0.0 1.872			K Factor @ node EQ01 Vel = 9.45	
102 to AA	33.81 99.27	1.682 120.0 0.2529	2V 1T	8.662 9.9 0.0	20.000 18.562 38.562	33.652 0.0 9.754			K Factor @ node EQ01 Vel = 14.33	
	0.0 99.27						43.406		K Factor = 15.07	
110 to 111	34.93	1.682 120.0 0.0366		0.0 0.0 0.0	16.000 0.0 16.000	35.903 0.0 0.586			K Factor @ node EQ01 Vel = 5.04	
111 to 112	35.21 70.14	1.682 120.0 0.1331		0.0 0.0 0.0	16.000 0.0 16.000	36.489 0.0 2.129			K Factor @ node EQ01 Vel = 10.13	
112 to AB	0.0 70.14	1.682 120.0 0.1330	2V 1T	8.662 9.9 0.0	20.000 18.562 38.562	38.618 0.0 5.129			Vel = 10.13	
	0.0 70.14						43.747		K Factor = 10.60	
AA to AB	99.27	2.635 120.0 0.0284		0.0 0.0 0.0	12.000 0.0 12.000	43.406 0.0 0.341			Vel = 5.84	
AB to AC	70.15 169.42	2.635 120.0 0.0764	1V	5.903 0.0 0.0	16.000 5.903 21.903	43.747 0.0 1.673			Vel = 9.97	
AC to AD	0.0 169.42	2.635 120.0 0.0764	1V	5.903 0.0 0.0	2.000 5.903 7.903	45.420 -0.866 0.604			Vel = 9.97	
AD to AE	0.0 169.42	2.635 120.0 0.0764	1V	5.903 0.0 0.0	3.000 5.903 8.903	45.158 0.0 0.680			Vel = 9.97	
AE to AF	0.0 169.42	2.635 120.0 0.0764	1V	5.903 0.0 0.0	2.000 5.903 7.903	45.838 0.866 0.604			Vel = 9.97	
AF to AG	0.0 169.42	2.635 120.0 0.0764	1X	14.827 0.0 0.0	3.000 14.827 17.827	47.308 0.0 1.362			Vel = 9.97	
AG to AH	0.0 169.42	2.635 120.0 0.0764	1X	14.827 0.0 0.0	75.500 14.827 90.327	48.670 0.0 6.899			Vel = 9.97	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Clark Insurance fitness room #1

Page 6
Date 8/18/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
AH to AI	0.0 169.42	2.635 120.0 0.0764	1V	5.903 0.0	67.000 5.903 72.903	55.569 0.0 5.569		Vel = 9.97		
AI to TOR	0.0 169.42	2.635 120.0 0.0764	2V	11.807 0.0	28.000 11.807 39.807	61.138 0.0 3.041		Vel = 9.97		
TOR to FLW	0.0 169.42	2.635 120.0 0.0762	1Fsp	0.0 0.0	5.000 0.0 5.000	64.179 5.166 0.381		* Fixed loss = 3 Vel = 9.97		
FLW to BOR	0.0 169.42	2.635 120.0 0.0770	1Zia	0.0 0.0	1.000 0.0 1.000	69.726 8.863 0.077		* Fixed loss = 6.698 Vel = 9.97		
BOR to H1	0.0 169.42	6.16 140.0 0.0009	1F 1G	10.042 4.304	250.000 14.346 264.346	78.666 0.0 0.243		Vel = 1.82		
H1 to H2	0.0 169.42	8.27 140.0 0.0002	1T 1G	55.354 6.326	140.000 61.680 201.680	78.909 0.0 0.044		Vel = 1.01		
H2 to H3	0.0 169.42	12.34 140.0 0.0	1T	93.767 0.0	95.000 93.767 188.767	78.953 0.0 0.006		Vel = 0.45		
H3 to TEST	100.00 269.42	6.16 140.0 0.0022	1G 1E 1T	4.304 20.084 43.037	10.000 67.425 77.425	78.959 -5.630 0.167		Qa = 100 Vel = 2.90		
	0.0 269.42					73.496		K Factor = 31.43		