

Fire Suppression System Design Specifications

Notes

System Materials

Item Number	Description	Quantity
87-120016-001	ADP Nozzle	3
WK-282666-000	ML-500 Link 500 F (260 C), ML, Orange	3
WK-282664-000	ML-360 Link 360 F (182 C), ML, Unpaint	1
60-120006-001	WHDR-400M Cylinder/Valve, 4 Gallon	2
60-120099-001	Universal Control Head Assembly	1
60-120110-001	Remote Manual Release, Combination	1
60-120074-001	1 1/2" NPT Mechanical Gas Valve	1
87-120019-001	R Nozzle	2
87-120017-001	F Nozzle	2



Designed & Installed by:
Firesafe Equipment
Po Box 1355
Auburn, ME 04211
207-784-7525

For:
PORTLAND ELKS LODGE