

**. . . Fire Protection by Computer Design**

Accendo Fire Protection, LLC  
38 Additon Road  
Greene, Maine 04236  
207-946-6182

Job Name : BEDECS MOB FIRST FLOOR  
Drawing : 2  
Location : 1945 CONGRESS STREET PORTLAND, MAINE  
Remote Area : 3  
Contract : 17-1015  
Data File : 3-17-1015 FIRST FLOOR.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** BEDECS MOB  
**Location:** 1945 CONGRESS STREET PORTLAND, MAINE  
**Drawing no:** 2  
**Date:** 8/22/17

**Design**

**Remote area number:** 3  
**Remote area location:** FIRST FLOOR  
**Occupancy classification:** LIGHT  
**Density:** .10 - Gpm/SqFt  
**Area of application:** 1135 - SqFt  
**Coverage per sprinkler:** 96/256 - SqFt  
**Type of sprinklers calculated:** RELIABLE KFR-CCS SPECIFIC APPLICATION UPRIGH  
**No. of sprinklers calculated:** 8  
**In-rack demand:** - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 341.010 - GPM @ 67.758 - Psi  
**Type of system:** WET  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 9/28/2000  
**Location:** 150'-0" FROM THE BUILDING  
**Source:** THE PORTLAND WATER DISTRICT

**Name of contractor:** ACCENDO FIRE PROTECTION LLC  
**Address:** 38 ADDITON ROAD GREENE, MAINE 04236  
**Phone number:** 946-6182  
**Name of designer:** CKD  
**Authority having jurisdiction:** SFM, PORTLAND  
**Notes: (Include peaking information or gridded systems here.)**  
REMOTE AREA RELIABLE SHEET BULLETIN 044 REV. C


# Water Supply Curve C

Accendo Fire Protection, LLC  
BEDECS MOB FIRST FLOOR

Page 2  
Date 8/22/17

City Water Supply:  
C1 - Static Pressure : 80  
C2 - Residual Pressure: 75  
C2 - Residual Flow : 1413

Demand:  
D1 - Elevation : 9.745  
D2 - System Flow : 241.01  
D2 - System Pressure : 67.758  
Hose ( Demand ) : 100  
D3 - System Demand : 341.01  
Safety Margin : 11.881



# Fittings Used Summary

Accendo Fire Protection, LLC  
BEDECS MOB FIRST FLOOR

Page 3  
Date 8/22/17

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
Length Units             Feet  
Flow Units                US Gallons per Minute  
Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Accendo Fire Protection, LLC  
BEDECS MOB FIRST FLOOR

Page 4  
Date 8/22/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
SP1	0.0	5.6	20.9	na	25.6	0.1	256	7.0
SP2	0.0	5.6	20.9	na	25.6	0.1	256	7.0
50	120.5	8	31.12	na	44.63	0.1	10	13.2
51	120.5	K = K @ L1	22.34	na	25.6			
52	120.5	K = K @ L1	22.63	na	25.77			
53	120.5	K = K @ L1	23.21	na	26.1			
54	120.5	K = K @ L1	23.51	na	26.27			
54A	120.5		24.51	na				
55	120.5	K = K @ L1	28.58	na	28.96			
55A	120.5		30.09	na				
56	120.5	K = K @ L2	34.36	na	31.75			
57	120.5	K = K @ L2	34.77	na	31.94			
NN	120.5		34.61	na				
NO	120.5		35.98	na				
O	120.5		35.99	na				
P	120.5		36.29	na				
Q	120.5		49.72	na				
R	108.33		55.52	na				
TOR	108.33		56.79	na				
HDR	102.0		60.22	na				
HDR1	102.0		60.62	na				
BASE	101.0		66.08	na				
TEST	98.0		67.76	na	100.0			

The maximum velocity is 19.16 and it occurs in the pipe between nodes 55A and O

# Final Calculations - Hazen-Williams - 2007

Accendo Fire Protection, LLC  
BEDECS MOB FIRST FLOOR

Page 5  
Date 8/22/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SP1 to L1	0 0	5.60	25.60 25.6	1 1.049	T 0.0 0.0	5.0 0.0 7.000	120 0.2054	20.898 0.0 1.438		Vel = 9.50	
L1			0.0 25.60					22.336		K Factor = 5.42	
SP2 to L2	0 0	5.60	25.60 25.6	1 1.049	T 0.0 0.0	5.0 0.0 7.000	120 0.2054	20.898 0.0 1.438		Vel = 9.50	
L2			0.0 25.60					22.336		K Factor = 5.42	
50 to NN	120.500 120.500	8.00	44.63 44.63	1 1.049	T 0.0 0.0	5.0 0.0 6.080	120 0.5743	31.118 0.0 3.492		Vel = 16.57	
NN			0.0 44.63					34.610		K Factor = 7.59	
51 to 52	120.500 120.500	5.42	25.60	1.5		0.0 0.0 0.0	14.080 0.0	22.336 0.0		K = K @ L1	
52 to 54A	120.500 120.500	5.42	25.77 51.37	1.5 1.682	L T 0.0	2.475 9.9 12.375	120 0.0748	22.626 0.0 1.888		Vel = 7.42	
54A			0.0 51.37					24.514		K Factor = 10.38	
53 to 54	120.500 120.500	5.42	26.10	1.5		0.0 0.0 0.0	14.080 0.0	23.214 0.0		K = K @ L1	
54 to 54A	120.500 120.500	5.42	26.26 52.36	1.5 1.682	T 0.0 0.0	9.9 0.0 12.900	120 0.0775	23.514 0.0 1.000		Vel = 3.77	K = K @ L1
54A to 55A	120.500 120.500		51.37 103.73	1.5 1.682	T 0.0 0.0	9.9 0.0 20.320	120 0.2743	24.514 0.0 5.574		Vel = 7.56	
55A			0.0 103.73					30.088		K Factor = 18.91	
55 to 55A	120.500 120.500	5.42	28.96	1	T	5.0 0.0 0.0	0.830 5.000	120 0.0	28.584 0.0	K = K @ L1	
55A to O	120.500 120.500		28.96 103.73 132.69	1.049 1.5 1.682		0.0 0.0 0.0	5.830 3.750 13.650	0.2580 120	1.504 30.088 5.906	Vel = 10.75	
O			0.0 132.69					35.994		K Factor = 22.12	
56 to 57	120.500 120.500	5.42	31.75	1.5		0.0 0.0 0.0	13.420 0.0	120 0.0	34.361 0.0	K = K @ L2	
57 to P	120.500 120.500	5.42	31.94 63.69	1.5 1.682	T 0.0 0.0	9.9 0.0 13.650	120 0.1113	34.773 0.0 1.519		Vel = 4.58	K = K @ L2
P										Vel = 9.20	

# Final Calculations - Hazen-Williams

Accendo Fire Protection, LLC  
BEDECS MOB FIRST FLOOR

Page 6  
Date 8/22/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 63.69					36.292		K Factor = 10.57	
NN to NO	120.500 120.500		44.63 44.63	1.5 1.682	L T 0.0	2.475 9.9 0.0	11.420 12.375 23.795	120 0.0 0.0576	34.610 0.0 1.371		Vel = 6.44
NO to O	120.500 120.500		0.0 44.63	3 3.26	0.0 0.0	5.460 0.0	120 0.0024	35.981 0.013		Vel = 1.72	
O to P	120.500 120.500		132.69 177.32	3 3.26	0.0 0.0	10.120 0.0	120 0.0294	35.994 0.298		Vel = 6.82	
P to Q	120.500 120.500		63.69 241.01	3 3.26	Fsp B L 2T S	0.0 13.44 6.72 40.319 21.503	118.540 81.982 200.522	120 3.000 0.0520	36.292 10.428	** Fixed Loss = 3	Vel = 9.26
Q to R	120.500 108.330		0.0 241.01	4 4.26	T 0.0	26.334 0.0	11.170 26.334	120 0.0141	49.720 5.271		Vel = 5.43
R to TOR	108.330 108.330		0.0 241.01	4 4.26	4L 0.0	31.601 0.0	58.330 31.601	120 0.0141	55.521 0.0		Vel = 5.43
TOR to HDR	108.330 102		0.0 241.01	4 4.26	T B 0.0	26.334 15.8 0.0	6.330 42.134 48.464	120 0.0141	56.792 2.742 0.684		Vel = 5.43
HDR to HDR1	102 102		0.0 241.01	4 4.26	T 0.0	26.334 0.0	2.000 26.334	120 0.0142	60.218 0.0		Vel = 5.43
HDR1 to BASE	102 101		0.0 241.01	4 4.26	E Zca 0.0	13.167 0.0	6.000 13.167	120 0.0141	60.619 5.186	** Fixed Loss = 4.753	Vel = 5.43
BASE to TEST	101 98		0.0 241.01	6 6.16	E G T	20.084 4.304 43.037	150.000 67.425 217.425	140 0.0018	66.076 1.299 0.383		Vel = 2.59
			100.00 341.01						67.758	Qa = 100.00 K Factor = 41.43	