
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager ROODS TRACY E		Inspector Tom Markley	Inspection Date 4/6/2005
Location 1909 CONGRESS ST	CBL 217 A003001	Status Re-Inspect 10 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-113.1	Interior	1		Kitchen	
Violation:	Lighting standards/Habitable rooms				
Notes:	Stove outlet wired incorrectly				
2) 6-113.5	Interior	b		Basement	
Violation:	Maintenance of lighting fixtures				
Notes:	Open junction boxes				
3) 6-113.5	Interior	b		Basement	
Violation:	Maintenance of lighting fixtures				
Notes:	wires hanging in basement (Could be hot or discontinued)				
4) 6-109.4	Exterior			rear yard	
Violation:	Disposal of rubbish, garbage and waste.				
Notes:	Dog Feces covering most of yard				

Comments: Master Electrician MUST be engaged to check the above violations and correct within 10 days