Exsting Rafter Contruction:
- 2x10 SPF #2 or Better
- 16-inch O/C

New Rafter Construction:
- 2x10 SPF #2 or Better
- 16-inch O/C

Dormer Opening and Framing Detail:
See Drawing D-1

CIR Enterprises	Discription:	Project: Proposed D
Customer: Stanford Brown Site: 3 Heritage Court, Portland, ME 04102	Rafter Detail	Date: 10/01/15 Drawing: FP-0

Date: 03/07/16

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

CITY OF PORTLAND, MAINE · RESURGAM