2 LIFE SAFETY PLAN

SCALE: 1/8" = 1'-0"

2' 4' 8' 16'

AREA NOT IN CONTRACT

IBC 2009 CODE DATA	
SUITE FLOOR AREA	3,940 SF
NUMBER OF STORIES	2ND OF 3
USE AND OCCUPANCY CLASSIFICATION – CHAPTER 3	B BUSINESS USE
TYPE OF CONSTRUCTION – TABLE 601	II-B
FIRE RESISTANT CONSTRUCTION – TABLE 601:	
STRUCTURAL FRAME	0 HOUR
EXTERIOR BEARING WALLS	0 HOUR
INTERIOR BEARING WALLS	0 HOUR
EXTERIOR NONBEARING WALLS	0 HOUR
INTERIOR NONBEARING WALLS	0 HOUR
FLOOR CONSTRUCTION	0 HOUR
ROOF CONSTRUCTION	0 HOUR
FIRE RATING STAIR ENCLOSURES – SECTION 1022.1	1 HOUR
SPRINKLER SYSTEM REQUIRED – SECTION 903	REQUIRED
FIRE ALARM SYSTEM REQUIRED – SECTION 907	REQUIRED
OCCUPANT LOAD – TABLE 1004.1.1	40
MAXIMUM COMMON PATH OF TRAVEL DISTANCE – NFPA 101-2009 TABLE A7.6	100 FEET
MAXIMUM EXIT TRAVEL DISTANCE – TABLE 1016.1	300 FEET
FIRE RATED CORRIDORS – TABLE 1018.1	N/A
DEAD END CORRIDOR LENGTH – SECTION 1018.4	50 FEET
MINIMUM NUMBER OF EXITS – TABLE 1021.2	2 PER FLOOR
FIRE EXTINGUISHERS	1 AT EACH EXIT 3-A 10-B:C
NOTES	

NFPA 101 2009 CODE DATA	
SUITE FLOOR AREA	3,940 SF
NUMBER OF STORIES	2ND OF 3
USE GROUP CLASSIFICATION – SECTION 3.3.178	SEE PLAN
TYPE OF CONSTRUCTION – NFPA 220	II (000)
FIRE RESISTANT CONSTRUCTION – NFPA 220:	
EXTERIOR BEARING WALLS	0 HOUR
INTERIOR BEARING WALLS	0 HOUR
COLUMNS	0 HOUR
BEAMS, GIRDERS, TRUSSES, AND ARCHES	0 HOUR
FLOOR CONSTRUCTION	0 HOUR
ROOF CONSTRUCTION	0 HOUR
EXIT STAIR ENCLOSURES – SECTION 7.1.3.2.1	1 HOUR
OCCUPANT LOAD – TABLE 7.3.1.2	40
PROTECTION OF VERTICAL OPENINGS – SECTION 12.3.1	N/A
MINIMUM NUMBER OF EXITS – TABLE A7.6	2 PER FLOOR
DEAD END CORRIDOR LENGTH – TABLE TABLE A7.6	50 FEET
MAXIMUM COMMON PATH OF TRAVEL DISTANCE – TABLE A7.6	100 FEET
MAXIMUM EXIT TRAVEL DISTANCE – TABLE A7.6	300 FEET
FIRE ALARM SYSTEM REQUIRED – SECTION 12.3.4.1.1	REQUIRED
SPRINKLER SYSTEM REQUIRED – SECTION 12.3.5	REQUIRED
FIRE RATED CORRIDORS – SECTION 12.3.6	N/A
FIRE EXTINGUISHERS	1 AT EACH EXIT 3-A 10-B:C
NOTES	

LIFE SAFETY PLAN KEY

- EXIT SIGN
- EMERGENCY LIGHT
- FE — FIRE EXTINGUISHER
- F — FIRE ALARM PULL STATION
- S — FIRE ALARM STROBE
- S — FIRE ALARM HORN STROBE
- 90' TRAVEL DISTANCE — EXIT TRAVEL DISTANCE
- 90' EXIT SEPARATION — EXIT SEPARATION DISTANCE

PLAN NORTH

TRUE NORTH

© 2017 Michael R. Charek, Architect

Michael Charek Architects

25 Hartley Street
Portland, Maine 04103
(207) 761-0556

REGISTERED ARCHITECT
MICHAEL R. CHAREK
No. 1174
STATE OF MAINE

Reviewed for Code Compliance
Inspections Division
Portland, Maine
Date: 12/12/17

Offices for Maxim Healthcare Services

Second Floor
1685 Congress Street, 2nd Floor
Portland, ME 04102

Title

LIFE SAFETY PLAN

Scale: 1/8"=1'-0"

Date: 11/16/17

Revisions

ISSUED FOR PERMIT

Sheet

A3