

CUNNINGHAM

Security Systems

10 Princes Point Road • Yarmouth, Maine 04096
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

May 15, 2012


Attn: Don McTherson
Code Enforcement Officer
City of Portland
389 Congress Street
Portland, ME 04101
Fax#: (207) 874-8716

Dear Mr. McTherson,

This letter is to inform you that on May 8, 2012, we completed the installation, programming and testing of a new fire alarm control panel at the Medical Office Building located at 1600 Congress Street in Portland, Maine. All the horn/strobes, pull stations, smoke detectors, sprinkler flow switches and sprinkler tamper switches were tied into this new fire alarm control and all these devices were programmed and test to NFPA 72 standards with test signals sent from these devices to our Central Monitoring Station. These devices were all found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File