



DIFFUSERS - GRILLES - REGISTERS

SYMBOL	MFG & MODEL #	SIZE	NC	P.D.	THROW
A	ANEROSTAT #EPL	6"φ	20	0.03	2-6
B	EPL	8"φ	20	0.01	3-8
C	EPL	10"φ	22.5	0.05	5-14
D	EPL	12"φ	22.5	0.03	7-17
E	S3HD	12"x12"	22.5	0.04	-
F	QCCL	12"x24"	22.5	0.04	-
G	QCCL	24"x24"	230	0.05	-
H	S2VO	12"x4"	220	0.02	9-15
J	S2VO	14"x6"	220	0.03	11-18
K	S2VO	16"x8"	220	0.02	13-20
L	S2VO	24"x8"	220	0.02	18-28

ALL AIR DEVICES SHALL BE WHITE

SYMBOLS

* PROVIDE & DUCT FOR INSTALLATION OF VAN DAMPERS IN THE FUTURE.

▽ ELECTRIC BASEBOARD HEAT WITH TSTAT. BY ELEC. SUB. WIRE THRU CONTRACTOR WITH 24 VOLT COIL. MECH. SUB. SHALL CONN. 24V. CONTACT TO TIME CLOCK.

EXHAUST FANS

EF-1, PENN # AT-24, 1/2 HP, 1000 RPM, 675 CFM @ 1/2" SP. W/ ROOF CURB & B.V. DAMPER, 120V-1φ-60HZ

EF-2, 3, 4, 5, PENN # XR-82, 1/2 HP, 1300 RPM, 900 CFM @ 1/2" SP. W/ ROOF CURB & B.V. DAMPER, 120V-1φ-60HZ

EF-4, PENN # AT-24, 1/2 HP, 1100 RPM, 500 CFM @ 1/2" SP. W/ ROOF CURB & B.V. DAMPER, 120V-1φ-60HZ

EF-6, PENN # XR-82, 1/2 HP, 1750 RPM, 400 CFM @ 1/2" SP. W/ ROOF CURB & B.V. DAMPER, 120V-1φ-60HZ

5.20.94 AS-BUILT DUGS
REVISED 12.6.99, EF-4 & EF-6

JOHNSON & JORDAN
MECHANICAL CONTRACTORS
P. O. BOX 1585
SCARBOROUGH, MAINE 04070-1585
TEL. (207) 883-8345
FAX (207) 883-8619

PROJECT: 1600 CONGRESS ST.

DR. BY: HWJ	PROJECT NO. 93155
DATE 10.30.99	SHT. NO. 1 OF 3

ISSUED FOR INFORMATIONAL PURPOSES ONLY
NOT FOR CONSTRUCTION

