

Work Change Proposal Request

AIA DOCUMENT G709

PROJECT:
Nephrology Associates Renovations
Portland, Maine

PROPOSED REQUEST NUMBER: 2

OWNER:
ARCHITECT:
CONSTRUCTION MANAGER:
CONTRACTOR:
FIELD:
OTHER:

Code Clarification Revisions

OWNER:
164 Realty LLC
100 Silver Street
Portland, ME 04101

DATE OF ISSUANCE: 2/16/2012
CONTRACT FOR: New Construction

FROM ARCHITECT:
CWS Architects
434 Cumberland Ave.
Portland, ME 04101

CONTRACT DATE: 1/20/2012

TO CONTRACTOR:
Wright/Ryan Construction
10 Danforth Street
Portland, Maine 04101

ARCHITECT'S PROJECT NUMBER: 11422

Please submit an itemized proposal for changes in the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. Within Zero (14) days, the Contractor must submit this proposal or notify the Architect, in writing, of the date on which proposal submission is anticipated.

THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED IN THE PROPOSED MODIFICATIONS.

DESCRIPTION:


Item No. 1: The contractor shall revise the fire rating of all new doors within Corridor 152 from 45 - minute doors to 60 - minute fire rated door units. This applies to doors 151B, 152A, 152B, 152C, 152D, 152E, 152F and 143.

Item No. 2: The contractor shall revise the partition tags at the new alcoves within Building Common Exit Corridor 152 from 4A-similar to 4D-similar. The similar in this case refers to the adjacent noting on the plans indicating that the partition height shall match the adjacent existing wall heights. These new walls are 1-hour fire rated assemblies as wall type 4D describes.

ATTACHMENTS:

None

REQUEST BY THE ARCHITECT:



(Signature)

Guy Labrecque, Architect, Vice President
(Printed name and title)