
55 Riverview

Philip DiPierro <pd@portlandmaine.gov>
To: Ann Machado <amachado@portlandmaine.gov>

Wed, Nov 15, 2017 at 5:31 PM

Hi Ann, I looked at the site today. The slope is stable and no erosion was noted. Some of the riprap has slumped, but vegetation has grown in these areas creating a stable slope. The riprap installation probably could have been done better, but it appears to be stable at this time. The slope for this site appears to be as stable as the rest of the slope for the abutting homes. See pics attached.

I have no issues with the site at this time.


Let me know if you have questions or if we need to discuss.

Thanks.

Phil

 [IMG_0199.JPG](#)

 [IMG_0200.JPG](#)


 [IMG_0201.JPG](#)

 [IMG_0202.JPG](#)

 [IMG_0203.JPG](#)

 [IMG_0204.JPG](#)

 [IMG_0205.JPG](#)

 [IMG_0206.JPG](#)

Philip DiPierro
Development Review Coordinator
City of Portland Planning Division
389 Congress Street
Portland, Maine 04101

Phone 207 874-8632
Fax 207 756-8258

[Quoted text hidden]