Inspections Division

Date: 12/09/16

In accordance with IRC 2009, ash cleanout openings will be within 6" of the base of each flue

The top of each opening will be more than 6" away from the respective inlets/thimbles

The openings will be greater than 6" high

The openings will be fitted with cast iron doors