Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/19/16

r Addition Structural Design
rvey Street
nd, Maine

- - - - INDICATES EXISTING BEARING WALL BELOW

INDICATES NEW SHEARWALL W/ MINIMUM OF 2x4 STUDS @ 16" O.C. AND ½" GYPSUM BOARD FASTENED @ 6" O.C. AT INTERIOR & ALL EDGES

INDICATES NEW BEARING WALL W/ 2x4 No. 2 SPF STUDS @ 16" O.C.

2nd FLOOR PLAN
1/8" = 1'-0"

N

SEE COVER LETTER AND CALCULATIONS DATED 2/12/2016 FOR LIMITATIONS & DESIGN CRITERIA.

CRITERIUM ENGINEERS
22 Monument Square
Portland, ME 04101
Tel (800) 242-1969
Fax (207) 775-4405
www.criterium-engineers.com

Sketch Title: 2nd FLOOR PLAN
Project: 28 HARVEY ST PORTLAND ME
Drawn by:
Checked by:
No.
Sheet 1 of 5
No.
Date 2/12/2016
Date