



ELECTRICAL FIXTURE SCHEDULE			
SYMBOL	FIXTURE	LAMP	NOTES
A	2 x 2 PARABOLIC	2-TT5	4" D. LOUVER, STANDARD PERFORMANCE
B	GROW LIGHT		
C	6" DIA. RECESSED FLORESCENT WALL WASHER		
D	8" DIA. RECESSED FLORESCENT DOWNLIGHT		
E	WALL SCONCE 1		
F	4' L SURFACE MOUNT FLORESCENT UTILITY	1-T8/T12	
G	WALL MOUNT FLORESCENT 2' FROM CEL: DAY-O-LIGHT JAZZ-W-PERF-40		
H	CLOSET FLORESCENT		
I	WALL SCONCE 2		
J	EXTERIOR RECESSED CEILING FIXTURE		
Δ	PHONE		
▽	DATA: CONDUIT W/ PULL STRING FOR WIRING TBD		
PH	PHONE PANEL		
CH	COMPUTER HUB		
CS	CALL SYSTEM: XRAY AREA IN EXISTING BUILDING, EXAM ROOMS, AND SECRETARY STATIONS WILL BE CONNECTED TBD		
SM	SM ALTERNATE: SNOW MELT SYSTEM: SWITCH TO CONTROL GLYCOL PIPING TO BE PLACED UNDER PAVERS		
EXIT	EXIT SIGNS		
EMERGENCY LIGHTS	EMERGENCY LIGHTS		
S	SMOKE DETECTOR		
\$	SINGLE POLE SWITCH 48" AFF TO TOP		
⌘	THREE WAY SWITCH 48" AFF TO TOP		
⌘	RHEOSTAT SWITCH 48" AFF TO TOP		
Ⓛ	DUPLEX OUTLET 18" AFF TO CENTER UNLESS NOTED		
Ⓛ	DOUBLE DUPLEX OUTLET 18" AFF TO CENTER UNLESS NOTED		
Ⓛ	SPECIAL PURPOSE OUTLET		
F	FIRE ALARM MANUAL STATION 48" AFF		
FK	FIRE ALARM HORN AND LIGHT UNIT 80" AFF NO CLOSER THAN 6" TO CEILING		
S#	FIRE ALARM VISUAL UNIT		

- ELECTRICAL NOTES**
- ALL ELECTRICAL WORK TO COMPLY WITH STATE AND LOCAL CODES.
 - E.C. TO COORDINATE WORK WITH OTHER SUB-CONTRACTORS, INCLUDING SPRINKLER INSTALLER AND SECURITY SYSTEM CONTRACTOR.
 - ALL ELECTRICAL FIXTURES, SWITCHES, DEVICES, ETC. TO BE NEW AND FREE OF ANY DAMAGE OR DEFECT.
 - WHEREVER POSSIBLE, E.C. WILL CENTER OUTLETS, SWITCHES, THERMOSTATS AND FIXTURES OVER ONE ANOTHER. PLACE TO PRESERVE WALL SPACE WHERE APPROPRIATE. CALL ARCHITECT WHEN IN DOUBT ABOUT HEIGHT OR LOCATION.
 - WHEREVER POSSIBLE, E.C. WILL COMBINE OUTLETS, SWITCHES, TELEPHONE AND TV JACKS ON THE SAME COVER PLATE.
 - LOCATION AND TYPE OF ALL FIRE ALARM, SMOKE DETECTOR, AND EMERGENCY LIGHTING TO BE APPROVED BY PERTINANT AUTHORITIES BEFORE INSTALLATION.
 - USE IC FRAME-IN KITS WHERE INSULATION OCCURS.
 - MOUNT EXTERIOR FIXTURES ON 3/4" x BLOCKS WHERE SHINGLES OCCUR.
 - E.C. TO VERIFY LOCATION OF BUILT-IN SHELVING, CAB'S, ETC., AND SET BOXES ACCORDINGLY.

1 REFLECTED CEILING PLAN/ELECTRICAL PLAN
E1 1/4 or 1/8