

HVAC - 11 KINGSMA



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/09/15

1- FLOOR PLAN

- * ATTACHED PICTURES SHOWS LOCATION TO BE USED FOR NEW GAS BOILER (WALL HUNG)
- * THE BOILER WILL BE MOUNTED ON 3/4" ADVANTECH PLYWOOD ANCHORED TO EXISTING CHIMNEY CINDER BLOCK.
- * FLOOR AREA IN FRONT OF BOILER IS APPROXIMATELY 4' x 4'

2- THE NEW GAS BOILER WILL USE THE EXISTING CHIMNEY LOCATION AS A CHASE STRAIGHT UP AND VENTED THROUGH THE ROOF WITH PVC PIPING.

3- EQUIPMENT SPECIFICATIONS ARE ATTACHED (GAS BOILER + 80 GALLON INDIRECT HOT WATER TANK)

4- PLOT PLAN ATTACHED BUT NOT APPLICABLE AS LOCATION OF UNIT AND VENTING DOES NOT CHANGE ON THE PROPERTY