389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To:	Janet Hansen	**From:**	Mike Nugent
Fax:	772-1070	**Date:**	May 12, 2004
Phone	772-3846	**Pages:**	1
Re:	131 Johnson Rd.(232 A005)		

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

I have commenced a partial review the submissions for the above permit and have the following questions:

1) The building was certified as being type 3B construction. The structural elements and sheathing appear to be wood which is not allowed in this classification
2) The spec book did not include Flame and Smoke info for carpet.
3) Need a stair and guard detail with dimensions
4) HVAC, Plumbing and Electrical plans are required, complete with fire separation assembly penetration plans (see Section 714)
5) What type of roofing is this anyway!!!!!!!!!!!!!!??