

•
•
•
•
•
•
•

389 Congress St.rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Janet Hansen **From:** Mike Nugent

Fax: 772-1070 **Date:** May 21, 2004

Phone: 772-3846 **Pages:** 1

Re: 131 Johnson Rd. (232 A005)

Urgent For Review Please Comment Please Reply Please Recycle



I have commenced the review of the submissions for the above permit and have the following questions:

- 1) I need new plans and specs showing the new type of construction as well as new certification forms.
- 2) I need a Stair and guard detail with dimensions
- 3) Still interested in Plumbing, Electrical and HVAC plans and FYI the only Fire damper exemption you get is for wall assemblies of one hour or less. Floor/ Ceiling Assemblies still need dampers.
- 4) I have issued the foundation permit, the remainder of this project will be placed in the hold bin until the required submissions are received.

