

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

440 WESTERN AVENUE ASSOCIATES LLP

Located at

131 JOHNSON RD

PERMIT ID: 2015-00403

ISSUE DATE: 09/18/2015

CBL: 232 A005001

has permission to **Install a 84 SF freestanding sign and a 24" x 192" (32 SF) attached building wall sign.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-00403	Date Applied For: 03/06/2015	CBL: 232 A005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Office - Dental Surgery & Boy Scouts Retail		Proposed Project Description: Install a 84 SF freestanding sign and a 24" x 192" (32 SF) attached building wall sign.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/18/2015
Note: B4 multi-tenant building Freestanding - Street frontage > 200' Max allow. Height 35' Proposed 13.5' OK Max allow. 100 SF Proposed 84 SF OK Building sign - Alternative 2 Principle façade<=5% 120.5' x 38'= 4,579 SF - 5%=229 SF allowed. 32SF proposed OK		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) Separate permits shall be required for any new signage. 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 03/12/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				