



Reviewed for Code Compliance
Inspection Division
Approved with Conditions
Date: 05/19/15



SR #: 335250



1 inch = 100 feet

Pressure Zone: 267

PORTLAND WATER DISTRICT
225 Douglass Street
Portland, ME 04104
Asset Management and Planning Dept.

Legend

● Air Valve	● Connection	⊕ Combined Service	● Manhole
● Blow Off	● Attribute Change	⊕ Domestic Service	● CSO
● By Pass	▲ Reducer	⊕ Fire Service	→ Gravity
⊕ Distribution	● Hydrant	● Private Hydrants	→ Force
⊕ Transmission	● Hydrant Control	⊕ Meter Pits	→ Contours

Hydrant Flow Testing Data

131 Johnson Road
Portland

This map depicts flow testing data for the selected hydrants from PWD's asset management system. Note: a static pressure with a zero residual pressure and a flow hydrant that is the same as the test hydrant depicts a single-hydrant static pressure-only test.

Drawn By: HAS	Prepared For: Ryan Ouellette Sprinkler Systems, Inc.
Scale: As Noted	Date: May 12, 2015