Owner: Distribution by Cianbro Corp. x Architect: JLH Consultant: Contractor: Ed Jones, Cianbro corp. Field: x Other: 03152/44.1, Log, RJL

SUPPLEMENTAL INSTRUCTION

AIA DOCUMENT G710

PROJECT: (name, address)

The Alton E "Chuck" Cianchette

INSTRUCTION NO: 1

Scout Service Center

OWNER: Pine Tree Council DATE OF ISSUANCE: 5/7/04

Boy Scouts of America

TO: (contractor)

Cianbro Corporation

ARCHITECT: SMRT, Inc.

144 Fore Street, PO Box 618

Attn: Ed Jones

Portland, ME 04104-0618

CONTRACT FOR: A/E PROJECT NO: 03152

New Construction

CONTRACT DATED: REFERENCES CONTRACTOR'S RFI NO. N/A

(if applicable)

The work shall be carried out in accordance with the following information which is issued as a clarification or interpretation of the contract documents. This is not a direction to proceed with work which modifies the Contract Sum or Contract Time. Proceeding with the Work in accordance with this supplemental instruction indicates your acknowledgement that there is no change in Contract Sum or Contract Time.

Description:

Revisions have been made to the following sheets:

GI002: Revised Wall Type 2 to 2-hour UL design.

AE100: Revised seats in showers. Revised dimension of elevator shaft and adjacent elevator machine room.

AE101: Revised wall tags at certain walls to create 1 hour rated enclosure of 2-story space. Added door and wall at Corridor 106.

AE102: Revised wall tags to create 1 hour rated enclosure of 2-story space. Eliminated sidelites at doors and windows between office space and 2-story space.

AE402: Revised dimensions of elevator shaft and machines room.

AE602: Revised door schedule as noted.

Reason:

Code compliance and adjusting dimensions to meet Otis Elevator requirements.

Attachments:

Sheets: GI002, AE100, AE101, AE102, AE211, AE402, AE602 Specification Sections: Revised 07811, Revised 08710, New 08331

ISSUED BY:
SMRT, INC.

Ganet & Hansen 5/6/04