

OCCUPANCY SENSOR SCHEDULE							
TYPE	DESCRIPTION	SENSOR TECHNOLOGY	SENSOR VOLTAGE	MANUFACTURER (OR APPROVED EQUAL)			NOTES
				SENSOR	POWER PACK	COVERAGE AREA	
1	WALL SWITCH SENSOR: SINGLE CIRCUIT W/ MANUAL CONTROL AND SELF ADAPTIVE TECHNOLOGY	PASSIVE INFRARED & ULTRASONIC	LINE	HUBBELL #LHMTS1	N/A	56'x50'	PROGRAM FOR MANUAL ON, AUTO OFF OPERATION
2	WALL SWITCH SENSOR: DUAL CIRCUIT W/ MANUAL CONTROL AND SELF ADAPTIVE TECHNOLOGY	PASSIVE INFRARED & ULTRASONIC	LINE	HUBBELL #LHMTD2	N/A	56'x50'	PROGRAM FOR MANUAL ON, AUTO OFF OPERATION
3	CEILING MOUNT SENSOR W/ SELF ADAPTIVE TECHNOLOGY	PASSIVE INFRARED & ULTRASONIC	LOW	HUBBELL #OMNIDT2000	MP POWER PACK	45'x45'	—
4	WALL MOUNT SENSOR W/ SELF ADAPTIVE TECHNOLOGY	PASSIVE INFRARED & ULTRASONIC	LOW	HUBBELL #LODT	MP POWER PACK	32'x32'	—



WALL CONTROLLERS

LUTRON
GRX-AV
CONTROL
INTERFACE

PROVIDE (2)#18
AWG TWISTED
PAIRS

A/V SYSTEM
COMPUTER
(BY OTHERS)

NOTE: CONTRACTOR SHALL PROVIDE ALL ACCESSORIES, MOUNTING HARDWARE, WIRING, AND PROGRAMMING FOR A COMPLETE AND OPERABLE SYSTEM. COORDINATE W/ MANUFACTURER'S RECOMMENDATIONS AND INSTALLATION GUIDELINES FOR SPECIFIC WIRING DIAGRAMS AND ADDITIONAL INFORMATION. PROGRAMMING WILL INCLUDE ALL PRESENT SCENES WHICH SHALL BE COORDINATED WITH THE OWNER AND INCLUDE FULL INTEGRATION OF LIGHTING, MOTORIZED SHADES, AND RS-232 CONNECTION TO A/V SYSTEMS SOFTWARE.

[illegible]

GRAPHIC SCALE:
0" 1'

SCALE: AS NOTED

PROJECT MANAGER: SLB

DATE: 11/15/05
 BY: JCM/CDS
 1/5 OF 50000
 IDB

CAD FILE: FI 653-060

PROJECT NO: 06016

DATE: 7-9-07

SHEET TITLE:
LIGHTING DETAILS

LIGHTING DETAILS AND RISERS

P

SHEET No. _____

EL653