



- A - STORMWATER DETENTION POND
- B1 - CATCH BASIN - SHIP 4 RECEIVING LOADING DOCK SLIDING TRUCK
- B2 - CATCH BASIN - SHIP 4 RECEIVING LOADING DOCK
- B3 - CATCH BASIN POWDER DOCK
- C1 - LIQUID NITROGEN TANK
- C2 - AMMONIA TANKS
- D - METAL CHIP STORAGE BIN
- D1 - EMPTY DRUM STORAGE
- D2 - UNDERGROUND STORAGE TANK
- E1 - INTERNAL MANHOLE ACCESS - STORMWATER SYSTEM
- F - POWDER METAL RECEIVING DOCK
- F1 - HAZARDOUS WASTE STORAGE
- F2 - USED OIL STORAGE
- F3 - HEAT TREAT PIT
- G - GARAGE
- J - ROOF ABOVE CONTACT AREA
- K - HYDROGEN TANK
- L - GENERATOR ROOM

**LEGEND**

EXISTING	DESCRIPTION	PROPOSED
---	PROPERTY/ROAD	---
---	SETBACK	---
---	EASEMENT	---
---	CENTERLINE	---
---	TRAIL	---
---	IRON PIPE/ROD	---
---	BUILDING	---
---	CONTOUR	---
---	STREAM	---
---	EDGE PAVEMENT	---
---	CURBLINE	---
---	TREELINE	---
---	TBST PIT	---
---	BORING	---
---	CONTOUR	---
---	GAO	---
---	BATER	---
---	SEWER	---
---	STORM DRAIN	---
---	UNDERDRAIN	---
---	OVERHEAD	---
---	ELEC. 1 TEL	---
---	UNDERGROUND ELEC. 1 TEL	---
---	GATE VALVE	---
---	LIGHT POLE	---
---	UTILITY POLE	---
---	BALL POINTED LIGHT	---
---	HYDRANT	---
---	CATCH BASIN	---
---	MANHOLE	---
---	CELEST	---
---	SPOT GRADE	---
---	CHAIN LINK FENCE	---
---	STOCKADE FENCE	---
---	STONE WALL	---
---	DECIDUOUS TREE	---
---	CONIFEROUS TREE	---
---	TRANSFORMER	---

**EXISTING CATCH BASIN SCHEDULE**

STRUCTURE	RFT ELEV.	INVERTS
CB-1	88.78	UNKNOWN
CB-2	88.82	UNKNOWN
CB-3	UNKNOWN	UNKNOWN
CB-4	UNKNOWN	UNKNOWN
CB-5	UNKNOWN	UNKNOWN
CB-6	80.64	18.00 (4" CAST IRON) 12.81 (2" SD TO CB-10) 14.88 (6" SD FROM DM-6) 14.88 (6" SD TO CB-8) 19.34 (4" CAST IRON) 14.88 (6" CAST IRON FROM CB-3)
CB-8	81.69	18.48 (6" CHD FROM CB-1) 18.28 (4" PVC) 18.69 (12" STEEL PIPE FROM CB-4) 19.25 (12" RCP TO DETENTION BASIN)
CB-9	76.31	UNKNOWN
CB-10	76.35	18.94 (6" CHD TO CB-10)
CB-11	74.36	68.24 (24" FROM CB-6) 68.65 (18" CHD FROM CB-10) 68.36 (24" CHD TO CB-16)
CB-12	UNKNOWN	UNKNOWN
CB-13	UNKNOWN	UNKNOWN
CB-14	UNKNOWN	UNKNOWN
CB-15	81.94	UNKNOWN
CB-16	UNKNOWN	UNKNOWN

**EXISTING DRAIN MANHOLE SCHEDULE**

STRUCTURE	RFT ELEV.	INVERTS
DM-1	86.04	UNKNOWN
DM-2	86.04	19.74 (CENTER OF STRUCTURE)
DM-3	86.04	UNKNOWN
DM-4	86.01	UNKNOWN
DM-5	86.01	12.5 (6" SD FROM DM-4) 8.3 (6" SD OF UNDERDRAIN) 12.26 (2" SD TO CB-4) 12.26 (2" SD TO CB-6) 11.88 (6" SD FROM CB-1)
DM-6	86.01	UNKNOWN

**EXISTING SEWER MANHOLE SCHEDULE**

STRUCTURE	RFT ELEV.	INVERTS
SM-1	81.73	18.48 (6" CAST IRON) 16.15 (6" CAST IRON TO DM-5)
SM-2	86.01	19.88 (6" SD) 14.23 (6" SD TO SM-3) 8.2 (6" SD)
SM-3	UNKNOWN	14.26 (6" SD FROM SM-1)



REV. BY. DATE. STATUS.

**STORMWATER SITE PLAN - FIGURE 2**  
OF  
**RODOLPH PORTLAND**  
2400 CONGRESS STREET  
PORTLAND, MAINE 04102  
FOR  
**PARKER-HANNIFIN CORPORATION**  
17325 EUCLID AVENUE  
CLEVELAND, OHIO 44112

**Sebago Technics**  
Engineering & Planning for the Future  
12 WESTBROOK COMMON  
WESTBROOK, ME 04091-1559  
TEL (207) 852-0277

DESIGN BY: DTM  
DRAWN BY: RLB  
CHECKED BY: DTM  
DATE: 8-22-84  
SCALE: 1"=40'  
FIELD NO.:  
PROJ. NO.: 83419  
**SHEET 10/11**