

Memorandum

To: Dana Sturdivant
From: Mike Nugent/Manager of Inspection Services
Date: 07/02/2004
Re: 2400 Congress St. (236 A003)

I have commenced reviewing the plans for the above project and need the following information:

- 1) Please provide the design standard that was used in calculating the Flat Roof Snow Load.
- 2) Please provide a code justification for the omission of footings for three of the four w18 x 31 vertical supports.
- 3) Is there any structural impact on the existing structure, ie additional loads to the abutting walls?
- 4) There is no source information for the steel, nor a fastener plan, sheathing and finish schedule fore the roofing materials.
- 5) This project will require Special Inspections for the Steel and fasteners pursuant to Section 1705 of the Code.
- 6) There is a vent for an appliance of some sort shown in the photo's. Please provide a plan showing how this will be redirected and also what type of appliance it vents.