

924413

237-A-008

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee _____ Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Portland Water District Phone # 774-5961

Address: 225 Douglass St - Ptd, ME 04104

LOCATION OF CONSTRUCTION 2300 Congress St.

Contractor: Suburban Propane Co Sub: 774-0387

Address: Thompson's PT - Ptd, ME 04102 Phone # _____

Est. Construction Cost: _____ Proposed Use: compost bldg

Past Use: _____ w tank

of Existing Res. Units _____ # of New Res. Units _____

Building Dimensions L _____ W _____ Total Sq. Ft. _____

Stories: _____ # Bedrooms _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion install one 1000-gln a/g propane tank

For Official Use Only

Date: 12/11/92 Subdivision: DEC 11 1992

Inside Fire Limits _____ Name _____

Bldg Code _____ Lot _____

Time Limit _____ Ownership: CITY OF PORTLAND Public _____ Private _____

Estimated Cost _____

Zoning: Street Frontage Provided: _____

Provided Setbacks: Front _____ Back _____ Side _____

Review Required: Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____

Special Exception _____

Other (Explain) _____

Ceiling:

1. Ceiling Joists Size: _____ Not in District nor Landmark.

2. Ceiling Strapping Size _____ Spacing _____ Does not require review.

3. Type Ceilings: _____ Requires Review.

4. Insulation Type _____ Size _____

5. Ceiling Height: _____ *****

Roof:

1. Truss or Rafter Size _____ Span _____ Approved with Conditions.

2. Sheathing Type _____ Size _____ Denied.

3. Roof Covering Type _____

Chimneys: Type: _____ Number of Fire Places _____

Heating: Type of Heat: _____

Electrical: Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____

2. Pool Size: _____ x _____

3. Must conform to National Electrical Code and State _____

Foundation:

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____

4. Joists Size: _____ Spacing 16" O.C.

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall if required _____

5. Other Materials _____

PERMIT ISSUED WITH REQUIREMENTS

Permit Received By Louise E. Chsae

Signature of Applicant Clarence Soucy Date Dec 11 1992

CEO's District _____

CONTINUED TO REVERSE SIDE

[4] Mr. Carroll

White - Tax Assessor

Ivory Tag - CEO

PERMIT ISSUED

~~HISTORIC PRESERVATION~~

PERMIT ISSUED WITH REQUIREMENTS

PLOT PLAN



Done w/out Insp.

FEES (Breakdown From Front)

Base Fee \$ 35-

Subdivision Fee \$ _____

Site Plan Review Fee \$ _____

Other Fees \$ _____

(Explain) _____

Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

Lawrence W. [Signature]
SIGNATURE OF APPLICANT

ADDRESS

7740387
PHONE NO.

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

PHONE NO.

BUILDING PERMIT REPORT

DATE: 12/10/92

ADDRESS: 2300 Congress St.

REASON FOR PERMIT: Install ABOVE GROUND L/P TANKS

BUILDING OWNER: Portland Water District

CONTRACTOR: Suburban Pipe

PERMIT APPLICANT Clarence Soucy

APPROVED: DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All above ground L/P storage tanks shall be located in accordance with NFPA #58 standards.
- 2.) Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.
- 3.) All piping shall be protected from possible mechanical damage and vandalism.

Congress street

Liberty matunw
2385 Cong. St

W H Nickols
Property

Driveway

Parking lot

Road

RECEIVED

DEC 03 1992

DEPT. OF BUILDING INSPECTIONS
CITY OF PORTLAND

Portland Water Dist
Compost Building

2300 Congress

Heaters → [diagram of two heaters]

Regulator

75-100'

Underground lines

1000 Gallon Tank

Yard

Gate

Fence → [dashed line]

