

From: Tom Errico <thomas.errico@tylin.com>
To: Jean Fraser <JF@portlandmaine.gov>
CC: David Margolis-Pineo <DMP@portlandmaine.gov>, Katherine Earley <KAS@port...>
Date: 9/17/2014 7:37 PM
Subject: 2282 Congress Street

Jean - I have reviewed the revised site layout, construction plan, and the off-site improvement plan and offer the following comments;

- * I find the site plan layout to be acceptable and I have no comment.
- * I find the construction plan to be acceptable with the requirement that a variable message board (s) be provided that notes use of Skyway Drive as an alternative route during construction.
- * The following are my comments regarding the improvement plan:
 - o The applicant should note why a minimum 5-foot shoulder is not provided (Please confirm that 4-feet is the existing width that the project is matching into)
 - o A detectible warning panel shall be installed on the easterly corner of Blueberry Road.
 - o Right-of-way boundaries on the north side of Congress Street should be provided and it should be confirmed that all activity will occur in the public right-of-way.
 - o A method for removal of existing conflicting pavement markings shall be provided for review and approval.

If you have any questions, please contact me.

Best regards,

Thomas A. Errico, PE
Senior Associate
Traffic Engineering Director
[T.Y. Lin International]T.Y. Lin International
12 Northbrook Drive
Falmouth, ME 04105
207.781.4721 (main)
207.347.4354 (direct)
207.400.0719 (mobile)
207.781.4753 (fax)
thomas.errico@tylin.com<mailto:thomas.errico@tylin.com>
Visit us online at www.tylin.com<http://www.tylin.com>
Twitter | Facebook | LinkedIn | YouTube

"One Vision, One Company"

Please consider the environment before printing.