

Location of Construction: 13 Blueberry Rd.		Owner: ** Marc Mason		Phone: 88 729-4164		Permit No: 000586	
Owner Address: Mason Veterinary Realty 257 Bath Rd. Brunswick, ME 04011		Lessee/Buyer's Name:		Phone:		Business Name:	
Contractor Name: Monaghan Woodworkers		Address: 111 Commercial St. Portland, ME		Phone: 775-2633		Permit Issued: JUN 1 2000	
Past Use: UNUM training facility		Proposed Use: veterinary hospital		COST OF WORK: \$ 420,000		PERMIT FEE: \$ 2544.00	
Proposed Project Description: new 360 sq addition		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: B Type: 5B BOCA 99		Zone: I-M CBL: 237-B-011	
		Signature:		Signature: <i>Hoffman</i>		Zoning Approval: <i>OK</i>	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: KA		Date Applied For: May 25, 2000		Signature:		Date:	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	ADDRESS:	DATE: May 25, 2000	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

PERMIT ISSUED WITH REQUIREMENTS
OG
SAM

CONTENTS

12 June 2K No work

23 June 2K - No work

25 July 2K - Demo. Started - question on bearing wall - Told Contractor to be careful

31 July 2K - Still doing demo.

18 Sept. 2K - Foundation 17 -

26 Sept. 2K, Framing completed left side and interior partitions.

2 OCT - 2K same -

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Building or Use Permit Pre-Application
Attached Single Family Dwellings/Two-Family Dwelling
Multi-Family or Commercial Structures and Additions Thereto**

In the interest of processing your application in the quickest possible manner, please complete the information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction (include Portion of Building): 13 BLUEBERRY ROAD PORTLAND, ME			
Total Square Footage of Proposed Structure 3770 S.F.		Square Footage of Lot 1.52 ACRES	
Tax Assessor's Chart, Block & Lot Number Chart# 237 Block# P5 Lot# 11		Owner: MARK MASON	Telephone#: 729-4164
Owner's Address: MASON VETERINARY REALTY, LLC		Lessee/Buyer's Name (If Applicable): 257 PATH RD, BRUNSWICK, ME 04011	Cost Of Work: \$420,000.00 Fee \$2544.00
Proposed Project Description: (Please be as specific as possible) NEW 360 SQ ADDITION to existing			
Contractor's Name, Address & Telephone MONAGHAN WOODWORKERS 111 COMMERCIAL ST. PORTLAND, ME			
Current Use: UNUM TRAINING FACILITY		Proposed Use: VETERINARY HOSPITAL	

Rec'd By **MR. 775-2683**

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must include the following with your application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design professional.

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:

Mark Mason

Date:

5/17/00


Building Permit Fee: \$30.00 for the 1st \$1000. cost plus \$6.00 per \$1,000.00 construction cost thereafter.
Additional Site review and related fees are attached on a separate addendum





CITY OF PORTLAND, MAINE

389 Congress St., Rm. 315
Portland, ME 04101
Tel. - 207-874-8704
Fax - 207-874-8716



TO: Inspector of Buildings City of Portland, Maine
Planning & Urban Development
Division of Housing & Community Services

FROM DESIGNER: JOSEPH DIDONATO
134 GUINEAS ROAD KENNEBUNKPORT, ME.

DATE: 5/19/00

Job Name: PORTLAND VETERINARY SPECIALISTS
Address of Construction: 13 BLUEBERRY ROAD PORTLAND, ME.

THE BOCA NATIONAL BUILDING CODE/1999 THIRTEENTH EDITION
Construction project was designed according to the building code criteria listed below:

Building Code and Year BOCA 99 Use Group Classification(s) BUSINESS
Type of Construction 5B Bldg. Height 25'-3 Bldg. Sq. Footage FIRST FLOOR MEZZANINE
Seismic Zone _____ Group Class _____
Roof Snow Load Per Sq. Ft. _____ Dead Load Per Sq. Ft. _____
Basic Wind Speed (mph) _____ Dead Load Per Sq. Ft. _____
Floor Live Load Per Sq. Ft. STAIRWELL 100 PSF

2800 S.F.
910 S.F.
3770 S.F.


Structure has full sprinkler system? Yes _____ No X Alarm System? Yes _____ No X
Sprinkler & Alarm systems must be installed according to BOCA and NFPA Standards with approval from the Portland Fire Department.


Is structure being considered unlimited area building: Yes _____ No X

If mixed use, what subsection of section 313.0 is being considered N/A

List Occupant loading for each room or space, designed into this Project. 100 S.F. CROSS.

(Designers Stamp & Signature)





City of Portland, Maine

ACCESSIBILITY CERTIFICATE

TO: Inspector of Buildings City of Portland, Maine
Department of Planning & Urban Development
Division of Housing & Community Services

FROM: JOSEPH DIDONATO

RE: Certificate of Design, HANDICAP ACCESSIBILITY

DATE: 5/19/00


These plans and/or specifications covering construction work on:

PORTLAND VETERINARY SPECIALISTS

13 BLUEBERRY ROAD, PORTLAND ME.

Have been designed and drawn up by the undersigned, a Maine registered engineer/architect according to State Regulations as adopted by the State of Maine on Handicapped Accessibility.

(SEAL)





Signature Joseph DiDonato

Title ARCHITECT

Firm DIDONATO ARCHITECTS

Address 134 QUINEA RD
KENNEBUNKPORT, ME.



**CITY OF PORTLAND
BUILDING CODE CERTIFICATE**

TO: Inspector of Buildings City of Portland, Maine
Department of Planning & Urban Development
Division of Housing & Community Service

FROM: JOSEPH DIDONATO

RE: Certificate of Design

DATE: 5/19/00


These plans and/or specifications covering construction work on:

PORTLAND VETERINARY SPECIALISTS

13 BLUEBERRY ROAD PORTLAND, ME.

Have been designed and drawn up by the undersigned, a Maine registered architect/engineer according to the BOCA National Building Code/1999 Thirteenth Edition, and local amendments.

(SEAL)



Signature Joseph Didonato

Title ARCHITECT

Firm DIDONATO ARCHITECTS

Address 134 GUINEA RD KENNEBUNKPORT, ME. 04046

As per Maine State Law:

\$50,000 or more in new construction, repair, expansion, addition, or modification for Building or Structures, shall be prepared by a Registered Design Professional.

ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION 114.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO CAD LT. 2000, OR EQUIVLENT.

BUILDING PERMIT REPORT

DATE: 26 MAY 2000 ADDRESS: 13 Blueberry Rd - 360 SQ FT Addition - Interior Renovation of CBL: 237-B-011
REASON FOR PERMIT: Change of Use From UNUM Training To Veterinary Hospital
BUILDING OWNER: MARC MASON
PERMIT APPLICANT: _____ CONTRACTOR: Monaghan Woodwork
USE GROUP: B CONSTRUCTION TYPE: 1B CONSTRUCTION COST: € 420,000 PERMIT FEES: 2544.0

The City's Adopted Building Code (The BOCA National Building code/1999 with City Amendments)
The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions are met: *1, *2, *3, *4, *11, *13, *17, *20, *23, *27, *29, *30, *34, *36

- *1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- *2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection) **"ALL LOT LINES SHALL BE CLEARLY MARKED BEFORE CALLING."**
- *3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- *4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' O.C. between bolts. Section 2305.17
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete from freezing. Section 1908.0
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1999)
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- *11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42". In occupancies in Use Group A, B, H-4, I-1, I-2, M, R, public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. Handrails shall be a minimum of 34" but not more than 38". Exception: Handrails that form part of a guard shall have a height not less than 36 inches (914 mm) and not more than 42 inches (1067 mm). Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0). Handrails shall be on both sides of stairway. (Section 1014.7)
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
- *13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1010.4)
16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closure's. (Over 3 stories in height requirements for fire rating is two (2) hours. (Section 710.0)
18. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1) w/s make separate

19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1999), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):

- In the immediate vicinity of bedrooms
- In all bedrooms
- In each story within a dwelling unit, including basements

*20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)

21. The Fire Alarm System shall be installed and maintained to NFPA #72 Standard.

22. The Sprinkler System shall be installed and maintained to NFPA #13 Standard.

*23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1999)

24. Section 25 - 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".

25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.

26. Ventilation and access shall meet the requirements of Chapter 12 Sections 1210.0 and 1211.0 of the City's Building Code. (Crawl spaces & attics).

*27. All electrical, plumbing and HVAC permits must be obtained by Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.

28. All requirements must be met before a final Certificate of Occupancy is issued.

*29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).

*30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)

31. Please read and implement the attached Land Use Zoning report requirements.


32. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.

33. Bridging shall comply with Section 2305.16.

*34. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2406.0)

35. All signage, shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code/1999).

*36. A structural analysis shall be done of the roof area if insulation is placed between all bays of the roof rafters. This is to make sure the roof system does not exceed its capability. If the snow load is increased due to no melting and staying on the roof for longer times,


Marge Schmuckal, Building Inspector

Cc: Lt. McDougall, PFD
Marge Schmuckal, Zoning Administrator

PSH 1/26/00

**This permit is herewith issued, on the basis of plans submitted and conditions placed on these plans, any deviations shall require a separate approval.

***THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD.

****ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION 114.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO CAD LT. 2000, OR EQUIVALENT.

*****CERTIFICATE OF OCCUPANCY FEE \$50.00

APPLICATION FOR EXEMPTION FROM SITE PLAN REVIEW

MARSH VETERINARY HEALTH, LLC.

May 23, 00

Applicant 257 PAUL ROAD BURNSWICK, MICH 48111
 Applicant's Mailing Address MELVIN
 Consultant/Agent/Phone Number 207.725.1200

Application Date Project Name/Description
BURNHAM VETERINARY SPECIALISTS
13 BURNSWICK RD. BURNSWICK
 Address of Proposed Site

Description of Proposed Development:

THE FOLLOWING PROPOSAL IS FOR THE ADDITION OF 360 SQ FT OF NEW FLOOR SPACE, & FEAT ENTRY & EXT CARRY KNOWNSI SPARE FACILITY. ~~WHICH SHALL INCLUDE THE RENOVATION OF THE EXISTING BUILDING.~~

Please Attach Sketch/Plan of Proposal/Development

Criteria for Exemptions:

See Section 14-523 (4)

- a) Within Existing Structures; No New Buildings, Demolitions or Additions
- b) Footprint Increase Less Than 500 Sq. Ft.
- c) No New Curb Cuts, Driveways, Parking Areas
- d) Curbs and Sidewalks in Sound Condition/ Comply with ADA
- e) No Additional Parking / No Traffic Increase
- f) No Stormwater Problems
- g) Sufficient Property Screening
- h) Adequate Utilities

Applicant's Assessment (Yes, No, N/A)	Planning Office Use Only
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>
<u>YES</u>	<u>OK</u>

Planning Office Use Only:

Exemption Granted Partial Exemption _____ Exemption Denied _____

Planner's Signature Suzanne Hopkins Date 5/25/00

White - Planning Office

Pink - Inspections

Yellow - Applicant