


WELD SHEAR TABS TO EXISTING COLUMNS (4)

ADD ADDITIONAL COLUMN SEE D1682-7 COLUMN (C-6)

GRATING ALL (3) SHELVES

- NOTES:
1. ALL DIMENSIONS AND ELEVATIONS ARE FOR REFERENCE. USE ONLY. CONTRACTOR SHALL FIELD VERIFY AND CHECK FOR ANY DISCREPANCIES PRIOR TO CONSTRUCTION. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER BEFORE PROCEEDING WITH THE EFFECTED PORTION OF WORK.
 2. PAINT ALL STEEL SURFACES PER SPEC. BELOW:
 - A. SURFACE PREP: SANDBLAST ALL SURFACES AS SPECIFIED IN STEEL STRUCTURES PAINTING COUNCIL GUIDE SSPC-SP2.
 - B. FINISH COAT WITH SHERWIN WILLIAMS "DURA-PLATE 235" MULTI-PURPOSE EPOXY, 4 MILS. THICK MIN.
 - C. COLOR: GRAY.
 ALTERNATE: HOT DIPPED GALVANIZED (OWNERS CHOICE)
 3. GROUT IN PLACE ALL BASEPLATES AFTER INSTALLATION USING FIVE STAR NON-SHRINKABLE GROUT OR EQUIVALENT.
 4. ROOFING IS FRP RESOLITE 7.2 IN X 1 1/2" RIB STYLE FIBERGLAS PANELS INSTALLED PER MANUFACTURERS RECOMMENDATIONS. FLASH ROOF TO WALLS.
 5. SEE DRAWINGS D1682-2 THRU D 1682-9 FOR DETAILS
 6. MARK IN 6" BLOCK LETTERS "CAPACITY 13000# PSF PER SHELF EVENLY DISTRIBUTED"
 7. ALL BOLTED CONNECTIONS SHALL BE ASTM A-325 GALVANIZED HIGH STRENGTH FASTENERS.
 8. GRATING MATERIAL: STEEL, TYPE GW-125 BEARING BAR: 1 1/4" X 3/16" SPACED @ 1 3/16" OC. CROSS BAR: SPACED @ 4" O.C. FINISH: GALVANIZED (ATTACH WITH GRATING CLIPS)



ECO MAINE
OUTDOOR STORAGE SHELVES
INSTALLATION

/Atlantic Engineering Services Inc. 12 PORTLAND NORTH BUSINESS PARK - FALMOUTH, MAINE 04106	
DESIGN: WACMASTER	SCALE: 1/4"=1'
DRAWN: WACMASTER	JOB NO.: 1682
APPROVED:	DATE: 7-30-12
NO.	REVISIONS
A	REDESIGNED
MADE BY:	DATE
CHKD BY:	
DRAWING NO.: D1682-1	REV. A