



FOOTING DETAIL
SCALE 1/2"=1'

SLAB DETAIL
SCALE 1/2"=1'

NOTES:

1. ALL DIMENSIONS AND ELEVATIONS ARE FOR REFERENCE USE ONLY. CONTRACTOR SHALL FIELD VERIFY AND CHECK FOR ANY DISCREPANCIES PRIOR TO CONSTRUCTION. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER BEFORE PROCEEDING WITH THE EFFECTED PORTION OF WORK.
2. CONCRETE SHALL DEVELOP A MINIMUM ULTIMATE COMPRESSIVE STRENGTH OF 4000 P.S.I. AT 28 DAYS. SLUMP TESTS ARE TO BE DONE WITH SLUMP OF 3"-6" AND (2) TEST CYLINDERS TAKEN, ONE TO BE TESTED AT 7 DAYS AND SECOND AT 28 DAYS. RESULTS TO BE SENT TO ECO MAINE.
3. ALL REINFORCING STEEL SHALL BE HARD BILLET STEEL AND CONFORM TO LATEST ASTM DESIGNATION A615, GRADE 60 PROVISION OF ACI 318-89.
4. ALL ANCHOR BOLTS SHALL CONFORM TO A-307 AND FURNISHED WITH (1) HEX. NUT & (1) FLAT WASHER UNLESS OTHERWISE SPECIFIED.

ECO MAINE OUTSIDE STORAGE
FOUNDATION PLAN

Atlantic Engineering Services Inc.
2 PORTLAND NORTH BUSINESS PARK - FALMOUTH, MAINE 04106

DESIGN: WAGMASTER	SCALE: 1/4"=1'
DRAWN: WAGMASTER	JOB NO.: 1682
APPROVED:	DATE: 11-12-11
NO.	REVISIONS
A	REDESIGNED
NO.	REVISIONS
NO.	REVISIONS

DRAWING NO.: D1682-2 REV. A