


Project Name PORTLAND ME - ECO-MAINE STORAGE STRUCTURE - MATERIALS TESTING  
 Client ECOMAINE  
 Material Type AGGREGATE SUBBASE  
 Material Source SHAW EARTHWORKS - RIVER ROAD PIT

Project Number 12-1121  
 Lab ID 16137G  
 Date Received 11/13/2012  
 Date Completed 11/16/2012  
 Tested By CRAIG TURCOTTE

<u>STANDARD</u> <u>DESIGNATION (mm/um)</u>	<u>SIEVE SIZE</u>	<u>AMOUNT PASSING (%)</u>	<u>MDOT 703.06 TYPE D</u> <u>SPECIFICATIONS (%)</u>
150 mm	6"	100	100
125 mm	5"	100	
100 mm	4"	100	
75 mm	3"	100	
50 mm	2"	92	
38.1 mm	1-1/2"	88	
25.0 mm	1"	84	
19.0 mm	3/4"	81	
12.5 mm	1/2"	76	
6.3 mm	1/4"	70	25 - 70
4.75 mm	No. 4	66	
2.00 mm	No. 10	64	
850 um	No. 20	48	
425 um	No. 40	28	0 - 30
250 um	No. 60	16	
150 um	No. 100	10	
75 um	No. 200	5.3	0.0 - 7.0

SAMPLE MEETS SPECIFICATION



Comments

  
 Roger E. Domingo