


Report of Moisture-Density

Method ASTM D-1557 MODIFIED Procedure C

Project Name PORTLAND ME - ECO-MAINE STORAGE STRUCTURE -
MATERIALS TESTING
Client ECOMAINE
Material Type EXISTING GRAVEL
Material Source ON SITE BORROW

Project Number 12-1121
Lab ID 16136G
Date Received 11/13/2012
Date Completed 11/16/2012
Tested By CHARLES CROMWELL


Moisture-Density Relationship Curve



Maximum Dry Density (pcf) 121.4
Optimum Moisture Content (%) 10.3
Percent Oversized 15.2%

Corrected Dry Density (pcf) **125.8**
Corrected Moisture Content (%) **9.0**

Comments


Roger E. Domingo