

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716	Permit No: 2016-01881	Date Applied For: 07/19/2016	CBL: 238 A008001
--	---------------------------------	--	----------------------------

Proposed Use: Same: Trash to Energy Regional Solid Waste Facility ("EcoMaine").	Proposed Project Description: Renovations to the existing men's locker room and new cleaning areas to prevent over-exposure to toxic chemicals for "EcoMaine".
---	--

Dept: Zoning	Status: Approved	Reviewer: Jeanie Bourke	Approval Date: 08/04/2016
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Conditions:			

Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 08/09/2016
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Conditions:			
<ol style="list-style-type: none"> 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 			

Dept: Engineering DPS	Status: Not Applicable	Reviewer:	Approval Date: 08/04/2016
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Conditions:			

Dept: Fire	Status: Approved w/Conditions	Reviewer: Michael White	Approval Date: 08/04/2016
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Conditions:			
<ol style="list-style-type: none"> 1) A separate Fire Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation. 2) All means of egress to remain accessible at all times. 3) All construction shall comply with 2009 NFPA 101, Chapter 40, Industrial Occupancies and Chapter 39 Existing Business Occupancies. 4) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation. 5) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). 6) All construction shall comply with City Code, Chapter 10. 			