NO EXCUSES!

FDB

Fire Document Box

The FDB is the perfect fit to meet the demanding code requirements today. NFPA 72 10.18.2.1.2.8 states that a cabinet must be "prominently labeled 'FIRE ALARM DOCUMENTS'."

An internal galvanized sleeve holds the documents safely and securely. The sleeve is easily removable to allow storage of a 1.5" 3 ring binder or other media. The galvanized sleeve also contains 2 hooks for key rings or thumb drives, a place for several business cards, a cutout for a 1.4 Oz. can of test gas and a slot where a standard CD "jewel" case can be stored. Access to the documents is via a high security lock with a 3/4" barrel.

Standard Features:

- Overall Dimensions are:
  12" Wide x 13.1" High x 2.25" Deep
- 3/4" barrel lock to secure door
- Piano Hinged Door w/Notes Sticker
- Removable document holder can hold 1" of 8.5" x 11" paperwork
- Powder Coat Red Finish
- 16 Gauge CRS construction
- Embossed:
  - Key Ring Hooks
  - Business Card Holder
  - CD Case Slot
- 1.4 Oz. can of detector smoke
- Custom screening with your logo

NEMA

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Made In U.S.A.

ISO 9001 REGISTERED COMPANY

ADA

ACEBOX
Space Age Electronics, Inc.
www.1sae.com
800.486.1723 Toll Free
508.485.0966 Local
508.485.4740 Fax

No Excuses, Just Solutions!

Date: 07/30/13

SPACE AGE ELECTRONICS, INC.

Specifications:

The Fire Document Box (FDB) shall be constructed of 16 gauge cold rolled steel (CRS); it shall be painted with a durable red powder coat paint. The front door shall be lettered with the words "FIRE ALARM DOCUMENTS" in White indelible letters 1" in height. The door of the FDB shall be locked with a keyed lock, 3/4" barrel. The cabinet shall contain a 16 gauge galvanized CRS sleeve. This sleeve shall allow for the storage of 1" of paper, test and inspection records, manuals and other important documents. The sleeve shall also facilitate the hanging of key rings and thumb drives (for data storage) along with business cards and space for a CD "jewel" case: The unit shall also contain a 1.4oz can of smoke detector test gas. Adheared inside the door shall be a "Notes" label for the recording of valuable information such as AHJ approvals, various system codes and the location of hard to find devices.

If so desired, the internal sleeve (held in by 2 wing nuts) may be removed and the space used to insert a 1.5" 3 ring binder.

Notes Sticker inside FDB Door

Ordering Information:

Part #	Description
SSU00672	FDB Fire Document Box
SSU00673	FDB Custom Logo/lock
(ask for Form FD10498 to order custom box)	
CK1	Replacement 1.4 Oz Test Gas

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/30/13