

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ECO MAINE

Located at

0 BLUEBERRY RD (64 Blueberry Road)

PERMIT ID: 2016-02506

ISSUE DATE: 11/22/2016

CBL: 238 A008001

has permission to **Water Based Fire Suppression System-ECOMAINE sprinkler head relocation project**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

Fire Official

/s/ Michael Russell, MS, Director

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

PERMIT ID: 2016-02506

Located at: 0 BLUEBERRY RD (64 Blueberry

CBL: 238 A008001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02506	Date Applied For: 09/26/2016	CBL: 238 A008001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Commercial	Proposed Project Description: Water Based Fire Suppression System-ECOMAINE sprinkler head relocation project			
Dept: Zoning Status: Approved w/Conditions Reviewer: Jennifer Thompson Approval Date: 11/22/2016		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.		
Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 09/27/2016		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) Sprinkler system installation shall comply with NFPA 13.		
		2) Sprinkler supervisory systems shall monitor for water flow and sprinkler supervisory signals via an approved fire alarm panel to central station. One smoke detector shall be located over the panel, a manual pull station located at the front door, and an audible water flow alarm provided. A separate Fire Alarm Permit is required from a certified fire alarm company. This review does not include approval of system design or installation.		
		3) All construction shall comply with 2009 NFPA 101, Chapter 9 Building Service and Fire Protection Equipment.		
		4) A Knox Box is required.		
		5) Application requires State Fire Marshal approval.		
		6) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).		
		7) All construction shall comply with City Code, Chapter 10.		