Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/18/13

LEGEND

	CABLE TRAY FOR COMMUNICATIONS AT BAR JOIST
EMG / NL TYPE	BODINE EMG. BALLASTED NIGHT LIGHT FIXTURE
TYPE	2X4 LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE)
TYPE	1X4 LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE, DIAGONAL LINE DENOTES NIGHT LIGHT)
TYPE	DOWN LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE)
S	SINGLE POLE SWITCH – MOUNTED 48" AFF TO TOP
S3	THREE WAY SWITCH – MOUNTED 48" AFF TO TOP – MOUNTED 48" AFF TO TOP
S4	FOUR WAY SWITCH
SM	MOTION SENSING SWITCH
	SPECIALTY OUTLET
C	GFI RECEPTACLE SUBSCRIPT IS FOR COUNTER HEIGHT OR WP FOR WEATHER PROOF
TYPE	DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED
TYPE	208 V RECEPTACLE
TYPE	DOUBLE DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED
J	JUNCTION BOX – SIZED AS REQUIRED
J HR	POWER POLE CONNECTION. PANEL AND CIRCUITING AS INDICATED
	DISCONNECT SWITCH – FUSED AS REQUIRED (DIAGONAL LINE INDICATES FUSED)
	ELECTRIC MOTOR CONTROLLER
	EXIT LIGHT ATLITE #PNLRU W/LED LAMPS BATTERY BACKUP
TYPE	EBU – EMERGENCY LIGHT BATTERY UNIT. 120V VOLT AC. BATTERIES TO BE RATED FOR 90 MINUTES FOR CONNECTED LOAD.
	TEL/DATA RECEPTACLES (HALF SHADED DENOTES TELEPHONE AND DATA, CLEAR TELEPHONE ONLY, SOLID DENOTES DATA ONLY)
	POWER FLOOR BOX
M	CEILING MOTION SENSOR
R	RELAY
CIRCUIT HP DEF_NUM ST	FRACTIONAL HP MOTOR
UNIT# CIRCUIT AMPERAGE	MECHANICAL EQUIPMENT
	PANELXX – PANELBOARD– SEE SCHEDULES FOR CIRCUITING
GFI	GROUND FAULT INTERRUPTER /W SURGE SUPPRESSOR
EWC	ELECTRIC WATER COOLER
EF	EXHAUST FAN
WP	WEATHERPROOF
PC	PARTIAL CIRCUIT
FBO	FURNISHED BY OTHERS
C	COUNTER HEIGHT (SEE MILLWORK DRAWINGS FOR HEIGHT)
H	HOSPITAL GRADE W/RED FACE AND PLATE. IF GFI, DEVICE TO HAVE SURGE SUPPRESSOR
IG	ISOLATED GROUND OUTLET /W SURGE SUPPRESSOR. ORANGE FACE AND PLATE
ST	MANUAL THERMAL OVERLOAD SWITCH
BD	BUSS DUCT
DTT	DRY TYPE TRANSFORMER
C	COUNTER

FIRE ALARM SYSTEM

F	FIRE ALARM MANUAL STATION 48" AFF
F	FIRE ALARM HORN AND LIGHT UNIT – MOUNT 80" AFF EXCEPT NO CLOSER THAN 6" TO CEILING. NUMBER DENOTES CANDELA RATING
T	SPRINKLER TAMPER SWITCH
FL	SPRINKLER WATERFLOW SWITCH
S	FIRE ALARM VISUAL UNIT (NUMBER DENOTES CANDELA RATING) 6'8" AFF
S	FIRE ALARM SMOKE DETECTOR "E" SUBSCRIPT DENOTES ELEVATOR RECALL.

DRAWINGS

E100–LEGENDS
E300–LIGHTING
E400–POWER

GENERAL NOTES:

1) ALL BRANCH CIRCUITS TO BE TYPE MC CABLE.
2) ALL ELECTRICAL MUST MEET NEC AND LOCAL CODES.
3) TELEPHONE AND DATA WIRING BY OTHERS
4) TEMPERATURE CONTROL WIRING BY OTHERS

STATE OF MAINE
MICHAEL L. CLAYPOOLE
#7824
LICENSED
PROFESSIONAL ENGINEER

BENNETT ENGINEERING
CONSULTING ENGINEERS
BENNETT ROAD, P.O. BOX 297, FREEPORT, MAINE 04032
(207) 865-9475

B·H Milliken
ELECTRICAL CONTRACTORS
175 ANDERSON STREET
PORTLAND, MAINE 04101
PHONE 879-1877
FAX: 774-1492

CROSS INS.

CONGRESS STREET
PORTLAND, MAINE

TITLE

LEGENDS

SCALE: NON

DATE: 3-29-13

SHEET

E100