Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/18/13

* SEE GENERAL NOTES

PLUMBING CHASE WALL		228
UNRATED	N.A.	

* SEE GENERAL NOTES

3 5/8" STEEL STUDS		224
1 HOUR RATED	U.L. No. U333	
6" STEEL STUDS		226
1 HOUR RATED	U.L. No. U333	

* SEE GENERAL NOTES

3 5/8" STEEL STUDS		214
UNRATED	N.A.	
6" STEEL STUDS		216
UNRATED	N.A.	

* SEE GENERAL NOTES

3 5/8" STEEL STUDS		230
UNRATED	N.A.	

GENERAL NOTES

1. PARTITIONS SHALL BE CARRIED TO THE FLOOR DECKING OF THE FLOOR ABOVE UNLESS NOTED OTHERWISE
2. IN BATH ROOMS, TOILET ROOMS, TRASH ROOMS, RECYCLING ROOMS, JANITOR ROOMS, MAINTENANCE ROOMS W/ GPDW WALLS, PROVIDE 5/8" MR GPDW IN LIEW OF REGULAR GPDW ON ALL PARTITIONS WITHIN THE ROOM
3. ALL GPDW TO BE TYPE-X GPDW
4. ALL MR GPDW TO BE TYPE-X MR GPDW
5. INSTALL A CONTINUOUS BEAD SEALANT BETWEEN ALL TOP AND BOTTOM WALL PLATES AND THE FLOOR & STRUCTURAL DECKING ABOVE.

010 — 2 HR RATED

010 — 1 HR RATED

STUD OR CMU SIZE

2X4 WOOD STUDS		010
1 HR FIRE-RATED	U.L. No. U465	

PARTITION OR WALL TAG No.

FIRE-RATING

U.L. DESIGN No., IF APPLICABLE

PARTITION LEGEND

NO SCALE

A1

ROBERT J. FOSTER – ARCHITECT
36 Groveside Road, Portland, Maine 04102
(207) 761-3822

REGISTERED ARCHITECT ROBERT J. FOSTER #1734 STATE OF MAINE

3-29-13

Project Title

CROSS INSURANCE RENOVATIONS

2331 CONGRESS STREET
Portland, Maine

Mark	Date	Description
	03-29-13	ISSUED FOR BID

Issue Dates

Drawing Title

CONSTRUCTION SYSTEMS

Drawing Number

A40.1