Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/18/13

NOTES:
1) REUSE EXISTING CIRCUITING FOR NEW LAYOUT
2) FINAL PANEL SCHEDULES WILL BE DONE AT COMPLETION
3) EXISTING PANELS ARE IN ROOM 103
4) SYSTEM VOLTAGE 120/208V.
5) CONNECT EMERGENCY BATTERY UNITS TO NEAREST LIGHTING CIRCUIT

FIRE ALARM SYSTEM

F	FIRE ALARM MANUAL STATION 48" AFF
F	FIRE ALARM HORN AND LIGHT UNIT – MOUNT 80" AFF EXCEPT NO CLOSER THAN 6" TO CEILING. NUMBER DENOTES CANDELA RATING
T	SPRINKLER TAMPER SWITCH
FL	SPRINKLER WATERFLOW SWITCH
S	FIRE ALARM VISUAL UNIT (NUMBER DENOTES CANDELA RATING) 6'8" AFF
S	FIRE ALARM SMOKE DETECTOR "E" SUBSCRIPT DENOTES ELEVATOR RECALL.

FLOOR PLAN
1/8" = 1'-0"
A1

STATE OF MAINE
MICHAEL L. CLAYPOOLE #7824
PROFESSIONAL ENGINEER

BENNETT ENGINEERING
CONSULTING ENGINEERS
BENNETT ROAD, P.O. BOX 897, FREEPORT, MAINE 04032
(207) 865-9475

B.H.Milliken
ELECTRICAL CONTRACTORS
175 ANDERSON STREET
PORTLAND, MAINE 04101
PHONE 879-1877
FAX: 774-1492

CROSS INS.
CONGRESS STREET
PORTLAND, MAINE

TITLE
POWER

SCALE: 1/8"=1'
DATE: 3-29-13
SHEET
E400

THESE ELECTRICAL DRAWINGS ARE THE PROPERTY OF B.H. MILLIKEN ELECTRICAL CONTRACTORS INC. AND FOR THEIR USE ONLY.