Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/18/13

REFLECTIVE CEILING PLAN
1/8" = 1'-0"
A1


ROBERT J. FOSTER – ARCHITECT
36 Groveside Road, Portland, Maine 04102
(207) 761–3822


REGISTERED ARCHITECT
ROBERT J. FOSTER #1734
STATE OF MAINE
3-29-13

Project Title

# CROSS INSURANCE RENOVATIONS

2331 CONGRESS STREET
Portland, Maine

## GENERAL NOTES

1. REFER TO ROOM FINISH SCHEDULES ON SHTS A61.1, A61.2 & A61.3 FOR CEILING HEIGHTS UNLESS NOTED OTHERWSE.
2. REFER TO MECHANICAL & ELECTRICAL DRAWINGS FOR ADDITIONAL INFORMATION AND CO–ORDINATION.
3. CONSTRUCT 5/8" FIRE RATED BOXES BEHIND ANY RECESSED LIGHTS OR OTHER RECESSED ELEMENTS TO MAINTAIN REQ'T FIRE RATINGS.
4. PROVIDE ACCESS PANELS WHERE NECESSARY TO ACCESS MECH. AND PLUMBING ITEMS (SHUT OFF VALVES, ETC...). ACCESS PANELS SHALL BE FIRE RATED WHERE PENETRATING FIRE RATED BARRIERS.

| Mark | Date | Description |
|---|---|---|
| | 03–29–13 | ISSUED FOR BID |

Issue Dates

Drawing Title

REFLECTIVE CEILING PLAN

Drawing Number

A70.1