



NOTE:

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- RELOCATE EIGHT EXISTING LIGHTS IN NEW CEILING GRID AS INDICATED ON SHEET EL101. RELOCATED FIXTURES TO BE RE-FED FROM BRANCH CIRCUIT THAT ADJACENT FIXTURES ARE FED FROM.

KEYED NOTE:

- EXISTING DISTRIBUTION PANELBOARDS AND TRANSFORMER THAT HAVE BEEN DE-ENERGIZED TO BE REMOVED AND RETURNED TO THE OWNER. STORE PANELS AND TRANSFORMER IN NEW UTILITY RM 1023. REMOVAL TO INCLUDE THE REMOVAL OF ALL CONDUIT & WIRING FEEDING EQUIPMENT. FEEDERS COMING OUT OF LANDP-2 TO BE LEFT ABANDONED ABOVE CEILING FOR FUTURE CONNECTION OF NEW FEEDERS FOR OLD LAN ROOM PANELBOARDS.
- EXISTING PANELBOARDS PP2-1, PP2-2 AND PP2-3 TO BE REMOVED INCLUDING REMOVAL OF EXISTING FEEDER BACK TO CIRCUIT BREAKER CB-PP2 LOCATED IN THE WAREHOUSE. SEE DRAWING EP101 FOR LOCATION OF CIRCUIT BREAKER CB-PP2. ANY REMAINING BRANCH CIRCUITS THAT REMAIN AFTER DEMOLITION SHALL BE EXTENDED TO NEW PANELBOARD PP1B LOCATED IN UTILITY ROOM 1023.
- REMOVE EXISTING SMOKE DETECTORS AND RELOCATE AT LOCATIONS SHOWN ON EY101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATIONS.
- EXISTING EMERGENCY LIGHTING UNIT AND EMERGENCY LIGHTING BATTERY CABINET TO BE RELOCATED TO NEW LOCATION SHOWN ON EL101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW LOCATION.
- REMOVE POWER FOR AUTOMATIC DOOR, PUSH PADS AND ALL ASSOCIATED CONDUIT & WIRING.
- RELOCATE SWITCH AT NEW LOCATION SHOWN ON EL101 TO CONTROL REMAINING LIGHT. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW SWITCH LOCATION.
- RELOCATE EXISTING FIRE ALARM NOTIFICATION DEVICE TO NEW LOCATION SHOWN ON EY101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATION.
- REMOVE AND RELOCATE TWO 2x2 PARABOLICS TO NEW EXTENSION OF EXISTING CORRIDOR. SEE DRAWING EL101 FOR NEW FIXTURE LOCATIONS.
- EXISTING LIGHTS TO BE REMOVED TO ALLOW REMOVAL OF CEILING GRID & INSTALLATION OF CABLE TRAY. RE-INSTALL LIGHTS AND RECONNECT TO EXISTING BRANCH CIRCUITS AFTER NEW CEILING GRID HAS BEEN INSTALLED.

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE
ISSUED FOR CONSTRUCTION		
12-21-17		
CURRENT ISSUE STATUS:		

PROJECT NORTH:
 SMART Architects and Engineers
 144 Fore Street
 Portland, Maine 04104
 1.877.700.7678
 www.smartinc.com

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY | **SMART**

**MAINE MEDICAL CENTER
 M.M.C. HUTCHINS DRIVE
 RENOVATION**
 102 HUTCHINS DRIVE, PORTLAND, ME

**FIRST FLOOR ELECTRICAL
 DEMOLITION PLAN**

SHEET TITLE:
 0 1/4" 1/2" 1" 2" 3"

SCALE: AS NOTED

PROJECT MANAGER:	RSC	PROJECT NO.:	17123
A/E OF RECORD:	DJT		
JOB CAPTAIN:	SDL		
DRAWN BY:	CDS		
SMART FILE:	ED101-17123	SHEET NO.:	ED101

FIRST FLOOR DEMOLITION PLAN (A1)
 1/8" = 1'-0"