



NOTE:

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- RELOCATE EIGHT EXISTING LIGHTS IN NEW CEILING GRID AS INDICATED ON SHEET EL101. RELOCATED FIXTURES TO BE RE-FED FROM BRANCH CIRCUIT THAT ADJACENT FIXTURES ARE FED FROM.

KEYED NOTE:

- EXISTING DISTRIBUTION PANELBOARDS AND TRANSFORMER THAT HAVE BEEN DE-ENERGIZED TO BE REMOVED AND RETURNED TO THE OWNER. STORE PANELS AND TRANSFORMER IN NEW UTILITY RM 1023. REMOVAL TO INCLUDE THE REMOVAL OF ALL CONDUIT & WIRING FEEDING EQUIPMENT. FEEDERS COMING OUT OF LANDP-2 TO BE LEFT ABANDONED ABOVE CEILING FOR FUTURE CONNECTION OF NEW FEEDERS FOR OLD LAN ROOM PANELBOARDS.
- EXISTING PANELBOARDS PP2-1, PP2-2 AND PP2-3 TO BE REMOVED INCLUDING REMOVAL OF EXISTING FEEDER BACK TO CIRCUIT BREAKER CB-PP2 LOCATED IN THE WAREHOUSE. SEE DRAWING EP101 FOR LOCATION OF CIRCUIT BREAKER CB-PP2. ANY REMAINING BRANCH CIRCUITS THAT REMAIN AFTER DEMOLITION SHALL BE EXTENDED TO NEW PANELBOARD PP1B LOCATED IN UTILITY ROOM 1023.
- REMOVE EXISTING SMOKE DETECTORS AND RELOCATE AT LOCATIONS SHOWN ON EY101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATIONS.
- EXISTING EMERGENCY LIGHTING UNIT AND EMERGENCY LIGHTING BATTERY CABINET TO BE RELOCATED TO NEW LOCATION SHOWN ON EL101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW LOCATION.
- REMOVE POWER FOR AUTOMATIC DOOR, PUSH PADS AND ALL ASSOCIATED CONDUIT & WIRING.
- RELOCATE SWITCH AT NEW LOCATION SHOWN ON EL101 TO CONTROL REMAINING LIGHT. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW SWITCH LOCATION.
- RELOCATE EXISTING FIRE ALARM NOTIFICATION DEVICE TO NEW LOCATION SHOWN ON EY101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATION.
- REMOVE AND RELOCATE TWO 2x2 PARABOLICS TO NEW EXTENSION OF EXISTING CORRIDOR. SEE DRAWING EL101 FOR NEW FIXTURE LOCATIONS.
- EXISTING LIGHTS TO BE REMOVED TO ALLOW REMOVAL OF CEILING GRID & INSTALLATION OF CABLE TRAY. RE-INSTALL LIGHTS AND RECONNECT TO EXISTING BRANCH CIRCUITS AFTER NEW CEILING GRID HAS BEEN INSTALLED.

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE
ISSUED FOR CONSTRUCTION		
12-21-17		
CURRENT ISSUE STATUS:		
PROJECT NORTH: SMRT Architects and Engineers 144 Fore Street Portland, Maine 04104 1.877.700.7678 www.smrtinc.com		
MAINE MEDICAL CENTER M.M.C. HUTCHINS DRIVE RENOVATION 102 HUTCHINS DRIVE PORTLAND, ME		
FIRST FLOOR ELECTRICAL DEMOLITION PLAN		
SHEET TITLE:		
SCALE: AS NOTED		
PROJECT MANAGER: RSC	PROJECT NO: 17123	
A/E OF RECORD: DJT		
JOB CAPTAIN: SDL		
DRAWN BY: CDS		
SMRT FILE: ED101-17123	SHEET NO.	

FIRST FLOOR DEMOLITION PLAN (A1)
1/8" = 1'-0"