



**NOTE:**

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- EXTEND EXISTING SIMPLEX FIRE ALARM SYSTEM TO NEW NOTIFICATION AND INITIATING DEVICES SHOWN. PROVIDE ALL BOXES, CONDUIT, WIRING, DEVICES, EQUIPMENT, POWER SUPPLIES AND PROGRAMMING TO MAINTAIN A COMPLETE & OPERABLE SYSTEM.

**KEYED NOTE:**

- NEW DUAL CHANNEL POWER POLES TO BE UTILIZED FOR OWNER INSTALLED VOICE/DATA WIRING.
- RELOCATE SMOKE DETECTOR FROM CURRENT LOCATION SHOWN ON ED101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATION.
- RELOCATE FIRE ALARM NOTIFICATION DEVICE FROM CURRENT LOCATION SHOWN ON ED101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATION.
- FURNISH & INSTALL A NEW 4" UNDERGROUND CONDUIT FROM SPRINKLER ROOM TO UTILITY POLE LOCATED IN FRONT OF THE BUILDING ON THE WEST SIDE OF HUTCHINS DRIVE. COORDINATE WITH OWNER FOR EXACT POLE TO RUN CONDUIT OUT TO.
- MOUNT DATA OUTLET 60" AFF TO CENTER OF DEVICE.
- PROVIDE EMPTY OUTLET BOX AND 3/4" CONDUIT TO ABOVE CEILING FOR OWNER INSTALLED CARD READERS.
- FURNISH & INSTALL A 4" CONDUIT RUN ABOVE CORRIDOR CEILING FROM SPRINKLER ROOM TO NEW MDF ROOM.

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE

**ISSUED FOR CONSTRUCTION**  
12-21-17

CURRENT ISSUE STATUS:

PROJECT NORTH:  
SMRT Architects and Engineers  
144 Fore Street  
Portland, Maine 04104  
1.877.700.7678  
www.smrtinc.com

STATE OF MAINE  
DAVID TIBBATTS  
LICENSED PROFESSIONAL ENGINEER  
1/31/15

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY

**MAINE MEDICAL CENTER  
M.M.C. HUTCHINS DRIVE  
RENOVATION**  
102 HUTCHINS DRIVE, PORTLAND, ME

**FIRST FLOOR  
SYSTEMS PLAN**

SHEET TITLE:

0 1/4" 1/2" 1" 2" 3"

SCALE: AS NOTED

PROJECT MANAGER: RSC	PROJECT NO: 17123
A/E OF RECORD: DJT	
JOB CAPTAIN: SDL	
DRAWN BY: CDS	
SMRT FILE: EY101-17123	SHEET NO. EY101

FIRST FLOOR PLAN (A1)  
1/8" = 1'-0"