


NOTE:
1. SEE SHEET M001 FOR LEGEND AND ABBREVIATIONS.

KEYNOTE NUMBER	KEYNOTE DESCRIPTION
1	REBALANCE RGD TO INDICATED AIRFLOW.
2	22"x14" SA & 22"x14" RA UP TO ERU-1 ON ROOF. REFER TO PL401 FOR PARTIAL ROOF PLAN.
3	RS/RL UP TO CONDENSING UNIT. SEE TO PL401 FOR PARTIAL ROOF PLAN.
4	BALANCE (E) RTU-2 TO PROVIDE 25% OA (ADJ.) TO MAINTAIN NEGATIVE SPACE PRESSURE RELATIONSHIP IN PRINTSHOP.
5	RELOCATED T-STAT.



HVAC DUCTWORK ROOF PART PLAN
1/8" = 1'-0" (A13)

SECOND FLOOR HVAC DUCTWORK NEW WORK PLAN
1/8" = 1'-0" (A1)

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE
ISSUED FOR CONSTRUCTION		
12-21-17		
CURRENT ISSUE STATUS:		
PROJECT NORTH: SMRT Architects and Engineers 144 Fore Street Portland, Maine 04104 1.877.700.7678 www.smrtinc.com		
MAINE MEDICAL CENTER M.M.C. HUTCHINS DRIVE RENOVATION 102 HUTCHINS DRIVE, PORTLAND, ME SECOND FLOOR HVAC DUCTWORK NEW WORK PLAN		
SHEET TITLE:		
SCALE: AS NOTED		
PROJECT MANAGER: RSC	PROJECT NO: 17123	
AVE OF RECORD: KDD		
JOB CAPTAIN: SDL		
DRAWN BY: CWF		
SMRT FILE: MH102-17123	SHEET NO:	
MH102		