

SECTION 260500	SECTION 260519	SECTION 260526	SECTION 260560	SECTION 262416																											
GENERAL REQUIREMENTS FOR ELECTRICAL WORK	LOW VOLTAGE ELECTRICAL CONDUCTORS	GROUNDING	INSTALLATION OF WIRE AND CABLE	PANELBOARDS																											
<p>PART 1 - GENERAL</p> <p>1.1 REFERENCES</p> <p>A. AS USED IN THIS SECTION, "PROVIDE" MEANS "FURNISH AND INSTALL"; "FURNISH" MEANS "TO PURCHASE AND DELIVER TO THE PROJECT SITE COMPLETE WITH EVERY NECESSARY APPURTENANCE AND SUPPORT AND TO STORE IN A SECURE AREA IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS"; AND "INSTALL" MEANS "TO UNLOAD AT THE DELIVERY POINT AT THE SITE OR RETRIEVE FROM STORAGE, MOVE TO POINT OF INSTALLATION AND PERFORM EVERY OPERATION NECESSARY TO ESTABLISH SECURE MOUNTING AND CORRECT OPERATION AT THE PROPER LOCATION IN THE PROJECT."</p> <p>1.2 EXAMINATION OF SITE</p> <p>A. BEFORE SUBMITTING A BID, THE ELECTRICAL CONTRACTOR SHALL VISIT AND CAREFULLY EXAMINE SITE TO IDENTIFY EXISTING CONDITIONS AND DIFFICULTIES THAT MAY AFFECT THE WORK OF THIS SECTION. NO EXTRA PAYMENT WILL BE ALLOWED FOR ADDITIONAL WORK CAUSED BY UNFAMILIARITY WITH SITE CONDITIONS.</p> <p>B. BEFORE STARTING WORK IN A PARTICULAR AREA OF THE PROJECT, THE ELECTRICAL CONTRACTOR SHALL EXAMINE THE CONDITIONS UNDER WHICH WORK MUST BE PERFORMED INCLUDING PREPARATORY WORK PERFORMED UNDER OTHER TRADES, AND REPORT CONDITIONS THAT MIGHT ADVERSELY AFFECT THE WORK IN WRITING TO CONSTRUCTION MANAGER. COMMENCEMENT OF WORK SHALL BE CONSTRUED AS COMPLETE ACCEPTANCE OF EXISTING CONDITIONS AND PREPARATORY WORK.</p> <p>1.3 SCOPE</p> <p>A. THE WORK TO BE ACCOMPLISHED UNDER THESE SPECIFICATIONS INCLUDES PROVIDING ALL LABOR, MATERIALS, EQUIPMENT, CONSUMABLE ITEMS, SUPERVISION, ADMINISTRATIVE TASKS, TESTS AND DOCUMENTATION REQUIRED TO INSTALL COMPLETE AND FULLY OPERATIONAL ELECTRICAL SYSTEMS AS DESCRIBED HEREIN AND SHOWN ON THE DRAWINGS. THE ELECTRICAL CONTRACTOR SHALL COMPLETELY COORDINATE THE WORK OF THIS SECTION WITH THE WORK OF OTHER TRADES.</p> <p>B. THE ELECTRICAL CONTRACTOR SHALL FILE PLANS, OBTAIN PERMITS AND LICENSES, PAY FEES AND OBTAIN NECESSARY INSPECTIONS AND APPROVALS FROM AUTHORITIES THAT HAVE JURISDICTION, AS REQUIRED TO PERFORM WORK IN ACCORDANCE WITH ALL LEGAL REQUIREMENTS. THE ELECTRICAL CONTRACTOR SHALL PAY UTILITY BACKCHARGES AND EXCESS COSTS AND PERFORM WORK IN ACCORDANCE WITH UTILITY COMPANY REQUIREMENTS.</p> <p>C. THE WORK SHALL BE COMPLETE FROM POINT OF SERVICE TO EACH OUTLET OR DEVICE WITH ALL ACCESSORY CONSTRUCTION AND MATERIALS REQUIRED TO MAKE EACH ITEM OF EQUIPMENT OR SYSTEM COMPLETE AND READY FOR OPERATION. THE WORK SHALL INCLUDE BUT NOT BE LIMITED TO THE FOLLOWING:</p> <ol style="list-style-type: none"> COMPLETE POWER AND LIGHTING DISTRIBUTION SYSTEMS INCLUDING, LIGHTING AND RECEPTACLE PANELBOARDS, OVERCURRENT DEVICES, RACEWAY, CABLE AND WIRE. BRANCH CIRCUITS AND DEVICES FOR POWER AND CONVENIENCE RECEPTACLES. COMPLETE INTERIOR LIGHTING SYSTEM INCLUDING NORMAL AND EMERGENCY FIXTURES, EXIT SIGNS, LAMPS, CONTROLS, TRIM AND ACCESSORIES. EXTENSION OF EXISTING FIRE ALARM AND DETECTION SYSTEM INCLUDING PULL STATIONS, AREA SMOKE DETECTORS, INDICATING APPLIANCES, AUXILIARY CONTACTS FOR EQUIPMENT INTERLOCKING, AND OTHER DEVICES SHOWN ON THE DRAWINGS. PROVIDE ALL PATHWAYS, ROUGH-IN, CONDUIT, CABLE TRAY AND EMPTY OUTLET BOXES FOR VOICE/DATA WIRING, WIRING, JACKS AND TERMINATION SHALL BE BY OWNER. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH MINE HEALTH NETWORK ENGINEERING INFRASTRUCTURE SPECIFICATIONS DATED MAY 2017. CONTROL WIRING NOT PROVIDED BY DIVISION 23. GROUNDING. ALL SUPPORT MATERIAL AND HARDWARE FOR RACEWAY AND ELECTRICAL EQUIPMENT. BRANCH CIRCUITS TO CONTROL PANELS AND DEVICES FURNISHED UNDER OTHER SECTIONS. TERMINATION OF ALL CABLE AND WIRE UNLESS OTHERWISE NOTED. INSTALLATION OF ACCESS PANELS IN CEILINGS AND WALL CONSTRUCTION. SEALING OF CEILING, WALL AND FLOOR PENETRATIONS. DEMOLITION. <p>1.4 RELATED WORK IN OTHER SECTIONS</p> <p>A. THE FOLLOWING WORK IS NOT INCLUDED IN THIS SECTION AND SHALL BE PERFORMED UNDER OTHER SECTIONS:</p> <ol style="list-style-type: none"> CONCRETE WORK, INCLUDING CONCRETE HOUSEKEEPING PADS AND OTHER PADS AND BLOCKS FOR VIBRATING AND ROTATING EQUIPMENT. CUTTING AND PATCHING OF MASONRY, CONCRETE, TILE, AND OTHER PARTS OF STRUCTURE, WITH THE EXCEPTION OF DRILLING FOR HANGERS AND PROVIDING HOLES AND OPENINGS IN METAL DECKS. PAINTING. TEMPORARY WATER, HEAT, GAS AND SANITARY FACILITIES FOR USE DURING CONSTRUCTION. CONTROL WIRING SPECIFICALLY INDICATED AS PART OF DIVISION 23. <p>B. THE ELECTRICAL CONTRACTOR SHALL IDENTIFY LOCATIONS OF PENETRATIONS, STRUCTURAL SUPPORTS, ETC. REQUIRED FOR THE COMPLETION OF THE WORK OF THIS SECTION TO THE GENERAL CONTRACTOR IN A TIMELY MANNER.</p> <p>1.5 CODES, STANDARDS, AND AUTHORITIES</p> <p>A. ALL WORK SHALL BE PERFORMED STRICTLY AS REQUIRED BY RULES, REGULATIONS, STANDARDS, CODES, ORDINANCES, AND LAWS OF LOCAL, STATE, AND FEDERAL GOVERNMENTS, AND OTHER AUTHORITIES THAT HAVE LAWFUL JURISDICTION. ADDITIONALLY, MATERIALS AND EQUIPMENT SHALL BE MANUFACTURED, INSTALLED AND TESTED AS SPECIFIED IN LATEST EDITIONS, (EXCEPT WHERE NOTED OTHERWISE), OF PUBLICATIONS, STANDARDS, RULINGS, AND DETERMINATIONS OF:</p> <ol style="list-style-type: none"> LOCAL AND STATE BUILDING, PLUMBING, MECHANICAL, ELECTRICAL, FIRE AND HEALTH DEPARTMENT AND PUBLIC SAFETY CODES AGENCIES. INTERNATIONAL BUILDING CODE (IBC), 2009 EDITION. INTERNATIONAL FIRE CODE (IFC), 2015 EDITION. INTERNATIONAL ENERGY CONSERVATION CODE (IECC), 2009 EDITION. NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) OCCUPATIONAL SAFETY AND HEALTH ACT (OSHA) FACTORY MUTUAL ASSOCIATION (FM) NATIONAL ELECTRICAL CODE (NEC), 2014 EDITION. NATIONAL ELECTRICAL SAFETY CODE (NESC). MAINE HEALTH NETWORK ENGINEERING INFRASTRUCTURE SPECIFICATIONS DATED MAY 2017. <p>B. ALL MATERIALS AND EQUIPMENT SHALL BE LISTED BY UNDERWRITERS LABORATORIES (UL), AND APPROVED FOR INTENDED SERVICE.</p> <p>C. WHEN REQUIREMENTS CITED IN THIS PARAGRAPH CONFLICT WITH EACH OTHER OR WITH CONTRACT DOCUMENTS, THE MOST STRINGENT REQUIREMENTS SHALL GOVERN CONDUCT OF WORK.</p> <p>1.6 CONTRACT DRAWINGS</p> <p>A. WORK TO BE PERFORMED UNDER THIS SECTION IS SHOWN ON THE CONTRACT DRAWINGS AND DESCRIBED IN THE SPECIFICATIONS.</p> <p>B. THE LISTING OF ELECTRICAL DRAWINGS DOES NOT LIMIT RESPONSIBILITY OF DETERMINING THE FULL EXTENT OF WORK REQUIRED BY CONTRACT DOCUMENTS. THE ELECTRICAL CONTRACTOR SHALL REFER TO ARCHITECTURAL, PLUMBING, HVAC, STRUCTURAL, AND OTHER DRAWINGS AND OTHER SECTIONS THAT INDICATE TYPES OF CONSTRUCTION WITH WHICH WORK OF THIS SECTION MUST BE COORDINATED. ELECTRICAL CONTRACTOR SHALL CHECK WITH THE GENERAL CONTRACTOR AND OTHER TRADES TO DETERMINE WHETHER THERE WILL BE ANY INTERFERENCE BY SUCH TRADES WITH THE ELECTRICAL WORK. IF THE ELECTRICAL CONTRACTOR FAILS TO CHECK WITH THE GENERAL CONTRACTOR AND THE ELECTRICAL WORK IS LATER FOUND TO INTERFERE WITH THEIR OTHER WORK, THE ELECTRICAL CONTRACTOR SHALL MAKE NECESSARY CHANGES, WITHOUT ADDITIONAL COST TO THE OWNER, TO ELIMINATE SUCH INTERFERENCE.</p>	<p>PART 1 - GENERAL</p> <p>1.1 GENERAL</p> <p>A. THE PROVISIONS OF SECTION 260500, GENERAL REQUIREMENTS FOR ELECTRICAL WORK APPLY TO THE WORK OF THIS SECTION.</p> <p>1.2 CODES AND STANDARDS</p> <p>A. PRODUCTS SHALL COMPLY WITH THE FOLLOWING CODES AND STANDARDS AND SHALL BE UL LISTED AND LABELED:</p> <table border="0"> <tr> <td>ASTM B-3</td> <td>SOFT OR ANNEALED COPPER WIRE</td> </tr> <tr> <td>ASTM B-8</td> <td>CONCENTRIC LAY STRANDED COPPER CONDUCTORS</td> </tr> <tr> <td>NEMA WC-5</td> <td>THERMOPLASTIC INSULATED WIRE AND CABLE FOR THE TRANSMISSION AND DISTRIBUTION OF ELECTRICAL ENERGY.</td> </tr> <tr> <td>UL 44</td> <td>RUBBER INSULATED WIRES AND CABLES</td> </tr> <tr> <td>UL 83</td> <td>THERMOPLASTIC INSULATED WIRES AND CABLES</td> </tr> </table> <p>1.3 SUBMITTALS</p> <p>A. MANUFACTURER'S PRODUCT DATA SHEETS.</p> <p>PART 2 - PRODUCTS</p> <p>2.1 GENERAL</p> <p>A. ALL CONDUCTORS SHALL BE ANNEALED COPPER IN ACCORDANCE WITH ASTM B-3.</p> <p>B. THE JACKET OF ALL WIRE SHALL BE PRINTED WITH THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> MANUFACTURER SIZE INSULATION TYPE MAXIMUM VOLTAGE UL LABEL <p>C. ALL INSULATION SHALL BE RATED 600 VOLT.</p> <p>2.2 POWER WIRING</p> <p>A. FEEDERS AND MOTOR BRANCH CIRCUITS SHALL BE TYPE XHHW-2.</p> <p>B. ALL POWER WIRING SHALL BE STRANDED, CLASS B STRAND IN ACCORDANCE WITH ASTM B-8, MINIMUM SIZE #12 AWG.</p> <p>2.3 BRANCH CIRCUITS</p> <p>A. ALL LIGHTING AND CONVENIENCE RECEPTACLE BRANCH CIRCUIT WIRING SHALL BE TYPE THHN/THWN.</p> <p>B. BRANCH CIRCUIT WIRING SHALL BE SOLID OR STRANDED CONDUCTOR, MINIMUM SIZE #12 AWG.</p> <p>2.4 CONTROL WIRING</p> <p>A. WIRING FOR CONTROL CIRCUITS SHALL BE THHN/THWN.</p> <p>B. CONTROL WIRING SHALL BE STRANDED, CLASS B STRAND IN ACCORDANCE WITH ASTM B-8, MINIMUM SIZE #14 AWG.</p> <p>2.5 FIXTURE WIRE</p> <p>A. WHERE HIGH TEMPERATURE FIXTURE WIRE IS REQUIRED IT SHALL BE SILICONE RUBBER TYPE SF-2.</p> <p>PART 3 - EXECUTION</p> <p>3.1 GENERAL</p> <p>A. ALL WIRE SHALL BE INSTALLED IN ACCORDANCE WITH SECTION 260560, INSTALLATION OF WIRE AND CABLE.</p> <p style="text-align: center;">END OF SECTION 260519</p>	ASTM B-3	SOFT OR ANNEALED COPPER WIRE	ASTM B-8	CONCENTRIC LAY STRANDED COPPER CONDUCTORS	NEMA WC-5	THERMOPLASTIC INSULATED WIRE AND CABLE FOR THE TRANSMISSION AND DISTRIBUTION OF ELECTRICAL ENERGY.	UL 44	RUBBER INSULATED WIRES AND CABLES	UL 83	THERMOPLASTIC INSULATED WIRES AND CABLES	<p>PART 1 - GENERAL</p> <p>1.1 GENERAL</p> <p>A. THE PROVISIONS OF SECTION 260500, GENERAL REQUIREMENTS FOR ELECTRICAL WORK, APPLY TO THE WORK OF THIS SECTION.</p> <p>1.2 CODES AND STANDARDS</p> <p>A. PRODUCTS SHALL COMPLY WITH THE FOLLOWING CODES AND STANDARDS AND SHALL BE UL LISTED AND LABELED.</p> <p>UL 488A WIRE CONNECTORS AND SOLDERING LUGS FOR USE WITH COPPER CONDUCTORS.</p> <p>UL 510 ELECTRICAL INSULATING TAPE</p> <p>PART 2 - PRODUCTS</p> <p>2.1 WIRE AND CABLE</p> <p>A. WIRE AND CABLE ARE SPECIFIED IN OTHER SECTIONS OF DIVISION 26.</p> <p>2.2 TERMINATIONS AND SPLICES</p> <p>A. POWER WIRING:</p> <ol style="list-style-type: none"> TERMINAL LUGS, CONNECTORS AND SPLICES SHALL BE TIN PLATED, HIGH CONDUCTIVITY COPPER COMPRESSION TYPE. THEY SHALL HAVE CHAMFERED BARRELS AND BE PERMANENTLY IDENTIFIED WITH CONDUCTOR SIZES. TERMINAL LUGS FOR CONDUCTORS NO. 3/0 AWG AND LARGER SHALL BE LONG BARREL NEMA TWO HOLE TYPE. SPLICES SHALL BE LONG BARREL BUTT TYPE WITH A CENTER STOP IN THE SPLICE BARREL. HYDRAULIC CRIMPING TOOLS WITH PROPER DIE SIZES WHICH REQUIRE FULL CLOSURE BEFORE REOPENING SHALL BE USED. <p>B. LIGHTING AND BRANCH CIRCUITS</p> <ol style="list-style-type: none"> SPLICES AND TAPS IN LIGHTING AND BRANCH CIRCUIT WIRING SHALL BE 3M SCOTCHLOK SPRING CONNECTORS OR EQUAL. METAL CLAD CABLE CONNECTORS. FOR NON-JACKETED METAL CLAD CABLE IN DRY LOCATIONS, CABLE TERMINATIONS SHALL BE O.Z. GEDNEY TYPE PK FOR USE WITH GALVANIZED STEEL ARMOR OR TYPE PK-A FOR USE WITH ALUMINUM ARMOR. CABLE TERMINATIONS SHALL BE PROVIDED WITH LOCKNUTS AND BUSHINGS. <p>PART 3 - EXECUTION</p> <p>3.1 RACEWAY APPLICATION</p> <p>A. OUTDOORS: APPLY RACEWAY PRODUCTS AS SPECIFIED BELOW UNLESS OTHERWISE INDICATED:</p> <ol style="list-style-type: none"> EXPOSED CONDUIT: GRG. CONCEALED CONDUIT ABOVEGROUND: GRG. UNDERGROUND CONDUIT: RNC, TYPE EPC-40-PVC BOXES AND ENCLOSURES: ABOVEGROUND: NEMA 250, TYPE 4X. <p>B. INDOORS: APPLY RACEWAY PRODUCTS AS SPECIFIED BELOW UNLESS OTHERWISE INDICATED:</p> <ol style="list-style-type: none"> EXPOSED, NOT SUBJECT TO PHYSICAL DAMAGE: EMT. EXPOSED AND SUBJECT TO SEVERE PHYSICAL DAMAGE: GRG. CONCEALED IN CEILINGS AND INTERIOR WALLS AND PARTITIONS: TYPE MC CABLE. CONNECTION TO VIBRATING EQUIPMENT (INCLUDING TRANSFORMERS AND HYDRAULIC, PNEUMATIC, ELECTRIC SOLENOID, OR MOTOR-DRIVEN EQUIPMENT): FMC, EXCEPT USE LFMC IN DAMP OR WET LOCATIONS. DAMP OR WET LOCATIONS: GRG. BOXES AND ENCLOSURES: NEMA 250, TYPE 1, EXCEPT USE NEMA 250, TYPE 4 STAINLESS STEEL IN DAMP OR WET LOCATIONS. ALL EMERGENCY BRANCH CIRCUITS AND FEEDERS TO BE INSTALLED IN EMT. <p>C. MINIMUM RACEWAY SIZE: 3/4" TRADE SIZE</p> <p>D. RACEWAY FITTINGS: COMPATIBLE WITH RACEWAYS AND SUITABLE FOR USE AND LOCATION.</p> <ol style="list-style-type: none"> RIGID AND INTERMEDIATE STEEL CONDUIT: USE THREADED RIGID STEEL CONDUIT FITTINGS UNLESS OTHERWISE INDICATED. COMPLY WITH NEMA FB 2.10. PVC EXTERNALLY COATED, RIGID STEEL CONDUITS: USE ONLY FITTINGS LISTED FOR USE WITH THIS TYPE OF CONDUIT. PATCH AND SEAL ALL JOINTS, WIKS, AND SCRAPES IN PVC COATING AFTER INSTALLING CONDUITS AND FITTINGS. USE SEALANT RECOMMENDED BY FITTING MANUFACTURER AND APPLY IN THICKNESS AND NUMBER OF COATS RECOMMENDED BY MANUFACTURER. EMT: USE SETSCREW OR COMPRESSION, STEEL FITTINGS. COMPLY WITH NEMA FB 2.10. FLEXIBLE CONDUIT: USE ONLY FITTINGS LISTED FOR USE WITH FLEXIBLE CONDUIT. COMPLY WITH NEMA FB 2.20. <p>E. DO NOT INSTALL ALUMINUM CONDUITS, BOXES, OR FITTINGS IN CONTACT WITH CONCRETE OR EARTH.</p> <p>3.2 PREPARATION OF RACEWAYS</p> <p>A. RACEWAYS SHALL BE SUBSTANTIALLY COMPLETED BEFORE ANY WIRING IS INSTALLED IN THEM. BEFORE ANY WIRING IS PULLED INTO A CONDUIT, THE CONDUIT SHALL BE CLEANED AND TESTED FOR OBSTRUCTIONS AND CLEARED OF FOREIGN MATERIAL THAT MAY BE FOUND.</p> <p>3.3 PULLING INTO RACEWAYS</p> <p>A. ALL POSSIBLE CARE SHALL BE TAKEN IN PULLING OF WIRING INTO CONDUITS OR OTHER RACEWAYS. THE CABLE REELS OR COILS SHALL BE SET UP IN SUCH A WAY THAT THE CONDUCTOR MAY BE TRAINED INTO THE RACEWAY AS DIRECTLY AS POSSIBLE WITH A MINIMUM NUMBER OF CHANGES OF DIRECTION OR AMOUNT OF BENDING. WHERE SEVERAL CABLES ARE CONTAINED IN ONE CONDUIT, ALL SUCH CABLES SHALL BE PULLED IN TOGETHER.</p> <p>B. THE USE OF PULLING LUBRICANTS SHALL BE RESTRICTED TO NON-HARDENING TYPE, APPROVED BY UL AND THE CABLE MANUFACTURER.</p> <p>3.4 SPLICES AND TERMINATIONS</p> <p>A. ALL POWER AND CONTROL WIRING SHALL BE CONTINUOUS AND SHALL NOT BE SPLICED UNLESS OTHERWISE INDICATED ON THE DRAWINGS.</p> <p>B. BOLTS, NUTS AND HARDWARE USED FOR TERMINATIONS SHALL BE SILICONE BRONZE.</p> <p>C. WHERE TERMINATIONS ARE MADE ON INSULATED BUSES, THE TERMINATIONS SHALL BE INSULATED USING THE PROPER TAPE(S) AND FILERS FOR THE VOLTAGE LEVEL OF THE CABLE.</p> <p>D. CONNECTIONS IN MOTOR TERMINAL BOXES SHALL BE MADE BY INSTALLING COMPRESSION TYPE LUGS ON THE MOTOR BRANCH CIRCUIT CONDUCTORS AND THE MOTOR LEADS AND BOLTING THE LUGS TOGETHER THEN INSULATING WITH MOTOR LEAD CONNECTION KITS, RAYCHEM, 3M OR EQUAL.</p> <p>3.5 IDENTIFICATION</p> <p>A. ALL POWER WIRING CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS:</p> <table border="0"> <tr> <td>PHASE</td> <td>208Y/120V</td> <td>480Y/277V</td> </tr> <tr> <td>PHASE A</td> <td>BLACK</td> <td>BROWN</td> </tr> <tr> <td>PHASE B</td> <td>RED</td> <td>ORANGE</td> </tr> <tr> <td>PHASE C</td> <td>BLUE</td> <td>YELLOW</td> </tr> <tr> <td>NEUTRAL</td> <td>WHITE</td> <td>GRAY</td> </tr> <tr> <td>GROUND</td> <td>GREEN</td> <td>GREEN</td> </tr> </table> <p style="text-align: center;">END OF SECTION 260560</p>	PHASE	208Y/120V	480Y/277V	PHASE A	BLACK	BROWN	PHASE B	RED	ORANGE	PHASE C	BLUE	YELLOW	NEUTRAL	WHITE	GRAY	GROUND	GREEN	GREEN	<p>PART 1 - GENERAL</p> <p>1.1 GENERAL</p> <p>A. THE PROVISIONS OF SECTION 260500, GENERAL REQUIREMENTS FOR ELECTRICAL WORK, APPLY TO THE WORK OF THIS SECTION.</p> <p>1.2 CODES AND STANDARDS</p> <p>A. PRODUCTS SHALL COMPLY WITH THE FOLLOWING CODES AND STANDARDS AND SHALL BE UL LISTED AND LABELED:</p> <p>NEMA AB-1 MOLDED CASE CIRCUIT BREAKERS</p> <p>NEMA PB-1 PANELBOARDS</p> <p>UL 50 ENCLOSURES FOR ELECTRICAL EQUIPMENT</p> <p>UL 67 PANELBOARDS</p> <p>UL 489 MOLDED CASE CIRCUIT BREAKERS AND CIRCUIT BREAKER ENCLOSURES</p> <p>1.3 SUBMITTALS</p> <p>A. MANUFACTURER'S PRODUCT DATA SHEETS.</p> <p>B. CIRCUIT BREAKER SCHEDULES.</p> <p>C. DIMENSIONED PLANS, ELEVATIONS, SECTIONS AND DETAILS.</p> <p>1.4 MANUFACTURERS</p> <p>A. SUBJECT TO COMPLIANCE WITH THE REQUIREMENTS OF THIS SECTION:</p> <p>SQUARE D GE SIEMENS CUTLER HAMMER</p> <p>PART 2 - PRODUCTS</p> <p>2.1 GENERAL</p> <p>A. PANELBOARDS SHALL BE OF THE SIZES, RATING AND ARRANGEMENT SHOWN ON THE DRAWINGS.</p> <p>B. PANELBOARDS SHALL BE PROVIDED COMPLETE WITH ALL OVERCURRENT DEVICES, ACCESSORIES AND TRIM.</p> <p>C. ALL PANELBOARDS SHALL BE PROVIDED WITH SAFETY BARRIERS FOR DEAD FRONT CONSTRUCTION.</p> <p>D. THE REQUIRED SHORT CIRCUIT RATINGS OF ASSEMBLED PANELBOARDS ARE SHOWN ON THE DRAWINGS. THE SHORT CIRCUIT RATINGS OF EVERY OVERCURRENT DEVICE IN THE PANEL SHALL MEET OR EXCEED THE PANEL RATING. UNLESS OTHERWISE NOTED ON THE DRAWINGS, SERIES RATED COMBINATIONS WILL NOT BE PERMITTED.</p> <p>E. PROVIDE THROUGH-FEED OR SUB-FEED LUGS AS INDICATED ON PANEL SCHEDULES.</p> <p>2.2 CABINETS</p> <p>A. BOXES SHALL BE CODE GAUGE GALVANIZED SHEET STEEL.</p> <p>B. TRIM SHALL BE CODE GAUGE STEEL, ANSI-61 GRAY FINISH WITH STAINLESS STEEL FLUSH TYPE LOCKLATCH HANDLE. ALL LOCKS SHALL BE KEYPED ALIKE.</p> <p>C. TRIM FOR SURFACE MOUNTED PANELS SHALL BE DOOR-IN-DOOR CONSTRUCTION SUCH THAT THE GUTTER SPACE MAY BE EXPOSED BY A HINGED DOOR.</p> <p>D. DIRECTORY FRAMES SHALL BE METAL FRAME WITH PLASTIC COVERS.</p> <p>2.3 BUS</p> <p>A. ALL BUS WORK SHALL BE COPPER.</p> <p>B. NEUTRAL BUSES SHALL BE 100% RATED WITH ADEQUATE CONNECTIONS FOR ALL OUTGOING NEUTRAL CONDUCTORS.</p> <p>C. PANELBOARDS SHALL BE PROVIDED WITH COPPER GROUND BUSES.</p> <p>D. BUS SHALL BE DESIGNED FOR SEQUENCE PHASE CONNECTION TO ALLOW THE INSTALLATION OF ONE, TWO OR THREE POLE BRANCH CIRCUIT BREAKERS IN ANY POSITION.</p> <p>2.4 OVERCURRENT DEVICES</p> <p>A. OVERCURRENT DEVICES SHALL BE TRIP-FREE MOLDED CASE, BOLT-ON, THERMAL-MAGNETIC CIRCUIT BREAKERS.</p> <p>B. MAIN CIRCUIT BREAKERS SHALL BE INDIVIDUALLY MOUNTED AND BOLTED TO BUS ASSEMBLY. BACK-FED BRANCH MOUNTED CIRCUIT BREAKERS ARE PROHIBITED.</p> <p>C. FRONT FACES OF ALL CIRCUIT BREAKERS SHALL BE FLUSH. TRIP INDICATION SHALL BE CLEARLY SHOWN BY THE HANDLE POSITION BETWEEN THE ON AND OFF POSITIONS.</p> <p>D. GROUND FAULT AND ARC FAULT CIRCUIT BREAKERS SHALL REQUIRE NO MORE PANEL SPACE THAN STANDARD BREAKERS.</p> <p>E. ALL CONNECTIONS SHALL BE RATED FOR 75° C COPPER CONDUCTORS.</p> <p>PART 3 - EXECUTION</p> <p>3.1 PANELBOARDS</p> <p>A. PANELBOARDS SHALL BE PROVIDED WITH A LABEL THAT INDICATES PANELBOARD NAME, VOLTAGE, AMPERAGE AND ELECTRICAL DISTRIBUTION EQUIPMENT THAT THE PANELBOARD IS FED FROM.</p> <p>B. PANELBOARD COVERS ARE REQUIRED TO HAVE 2 LABELS. THE FIRST AN ARC FLASH WARNING LABEL AND THE SECOND, AN OSHA LABEL REQUIRING 3 FEET, (3 FEET 6 INCHES OR 4 FEET AS APPLICABLE), CLEARANCE IN FRONT OF THE PANEL.</p> <p style="text-align: center;">END OF SECTION 262416</p>
ASTM B-3	SOFT OR ANNEALED COPPER WIRE																														
ASTM B-8	CONCENTRIC LAY STRANDED COPPER CONDUCTORS																														
NEMA WC-5	THERMOPLASTIC INSULATED WIRE AND CABLE FOR THE TRANSMISSION AND DISTRIBUTION OF ELECTRICAL ENERGY.																														
UL 44	RUBBER INSULATED WIRES AND CABLES																														
UL 83	THERMOPLASTIC INSULATED WIRES AND CABLES																														
PHASE	208Y/120V	480Y/277V																													
PHASE A	BLACK	BROWN																													
PHASE B	RED	ORANGE																													
PHASE C	BLUE	YELLOW																													
NEUTRAL	WHITE	GRAY																													
GROUND	GREEN	GREEN																													

REV	DESCRIPTION	DATE
1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17

ISSUED FOR CONSTRUCTION
12-21-17

CURRENT ISSUE STATUS:

--	--

SMRT Architects and Engineers
144 Fore Street
Portland, Maine 04104
1.877.700.7678
www.smrtinc.com

SMRT

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY

**MAINE MEDICAL CENTER
M.M.C. HUTCHINS DRIVE
RENOVATION**
102 HUTCHINS DRIVE PORTLAND, ME

SPECIFICATIONS

SHEET TITLE:

SCALE: AS NOTED

PROJECT MANAGER:	RSC	PROJECT NO.:	17123
A/E OF RECORD:	DJT		
JOB CAPTAIN:	SDL		
DRAWN BY:	CDS		

E-002

SMRT FILE: E-002-17123 SHEET NO. (continued on next sheet)