



**NOTE:**

- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- EXTEND EXISTING SIMPLEX FIRE ALARM SYSTEM TO NEW NOTIFICATION AND INITIATING DEVICES SHOWN. PROVIDE ALL BOXES, CONDUIT, WIRING, DEVICES, EQUIPMENT, POWER SUPPLIES AND PROGRAMMING TO MAINTAIN A COMPLETE & OPERABLE SYSTEM.

**KEYED NOTE:**

- SEE SHEET EP102 FOR FLOOR BOX SPECIFICATION.
- RELOCATE SMOKE DETECTOR FROM CURRENT LOCATION SHOWN ON ED101. EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW DEVICE LOCATION.
- MOUNT DATA OUTLET 60" AFF TO CENTER OF DEVICE.
- PROVIDE EMPTY OUTLET BOX AND 3/4" CONDUIT TO ABOVE CEILING FOR OWNER INSTALLED CARD READERS.
- MOUNT SMOKE DETECTORS INSIDE NEW ERU-1 SUPPLY AND RETURN DUCTS AND PROVIDE A REMOTE TEST STATION WALL MOUNTED IN SECOND FLOOR ELECTRICAL ROOM. UPON ACTIVATION DUCT SMOKE DETECTORS TO SHUT DOWN ERU-1 AND REPORT A TROUBLE SIGNAL TO THE FIRE ALARM CONTROL PANEL.

**SECOND FLOOR PLAN** (A1)  
1/8" = 1'-0"

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE

**ISSUED FOR CONSTRUCTION**  
12-21-17

CURRENT ISSUE STATUS:

**PROJECT NORTH:**  
 SMART Architects and Engineers  
 144 Fore Street  
 Portland, Maine 04104  
 1.877.700.7678  
 www.smartinc.com

**MAINE MEDICAL CENTER**  
**M.M.C. HUTCHINS DRIVE**  
**RENOVATION**  
 102 HUTCHINS DRIVE PORTLAND, ME

**SECOND FLOOR**  
**SYSTEMS PLAN**

SHEET TITLE:  
 0 1/4" 1/2" 1" 2" 3"

SCALE: AS NOTED

PROJECT MANAGER: RSC	PROJECT NO: 17123
A/E OF RECORD: DJT	
JOB CAPTAIN: SDL	
DRAWN BY: CDS	
SMART FILE: EY102-17123	SHEET No.

**EY102**