



NOTE:
1. SEE SHEET M001 FOR LEGEND AND ABBREVIATIONS.

KEYNOTE NUMBER	KEYNOTE DESCRIPTION
1	REBALANCE RGD TO INDICATED AIRFLOW.
2	22'x14" SA & 22'x14" RA UP TO ERU-1 ON ROOF. REFER TO PL401 FOR PARTIAL ROOF PLAN.
3	RS/RL UP TO CONDENSING UNIT. SEE TO PL401 FOR PARTIAL ROOF PLAN.
4	BALANCE (E) RTU-2 TO PROVIDE 25% OA (ADJ.) TO MAINTAIN NEGATIVE SPACE PRESSURE RELATIONSHIP IN PRINTSHOP.
5	RELOCATED T-STAT.

HVAC DUCTWORK ROOF PART PLAN
1/8" = 1'-0" (A13)

SECOND FLOOR HVAC DUCTWORK NEW WORK PLAN
1/8" = 1'-0" (A1)

1	ADDENDUM 1	1-9-18
0	ISSUED FOR CONSTRUCTION	12-21-17
REV	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
12-21-17

CURRENT ISSUE STATUS:

PROJECT NORTH:
SMRT Architects and Engineers
144 Fore Street
Portland, Maine 04104
1.877.700.7678
www.smrtinc.com

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY | **SMRT**

MAINE MEDICAL CENTER
M.C. HUTCHINS DRIVE
RENOVATION
102 HUTCHINS DRIVE, PORTLAND, ME

SECOND FLOOR HVAC DUCTWORK
NEW WORK PLAN

SHEET TITLE:
0 1/4" 1/2" 1" 2" 3"

SCALE: AS NOTED

PROJECT MANAGER: RSC PROJECT NO: 17123
AVE OF RECORD: KDD
JOB CAPTAIN: SDL
DRAWN BY: CWF
SMRT FILE: MH102-17123 SHEET NO.

MH102