FIRE PROTECTION NOTES:

1. SEE FP001 FOR LEGEND, DETAILS AND SPECIFICATIONS.
2. REWORK EXISTING SPRINKLER LAYOUT PER NFPA 13 REQUIREMENTS TO MATCH NEW CEILING GRID (RE:ARCHITECTURAL).
3. MODIFY AND REWORK EXISTING SPRINKLER SYSTEMS TO AVOID CONFLICTS WITH HVAC, CEILING HEIGHT CHANGES AND OTHER NEW INSTALLATIONS.
4. CONTRACTOR SHALL VERIFY EXISTING CONDITIONS AND IDENTIFY POTENTIAL CONFLICTS WITH NEW INSTALLATION PRIOR TO FINALIZING PROJECT BID. CHANGE ORDERS BASED ON CONFLICTS BETWEEN EXISTING PIPING AND NEW INSTALLATIONS WILL NOT BE ALLOWED.

KEYNOTES

KEYNOTE NUMBER	KEYNOTE DESCRIPTION
1	MODIFY AND REWORK SPRINKLER SYSTEM THROUGHOUT AREA OF RENOVATION IN ACCORDANCE WITH NFPA 13 TO ACCOMMODATE ARCHITECTURE MODIFICATIONS, CEILING LAYOUTS, AND HVAC INSTALLATIONS.

SECOND FLOOR FIRE PROTECTION PLAN (A1)
1/8" = 1'-0"

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/09/18

REV	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	12-21-17

ISSUED FOR CONSTRUCTION
12-21-17
CURRENT ISSUE STATUS:

PROJECT NORTH:

STATE OF MAINE — KERRY D. DINEEN 13301 — PROFESSIONAL ENGINEER — 12-21-17

SMRT Architects and Engineers
144 Fore Street
Portland, Maine 04104
1.877.700.7678
www.smrtinc.com
ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY

MAINE MEDICAL CENTER
M.M.C. HUTCHINS DRIVE
RENOVATION
102 HUTCHINS DRIVE PORTLAND, ME

SECOND FLOOR
FIRE PROTECTION PLAN

SHEET TITLE:

0 1/4" 1/2" 1" 2" 3"
SCALE: AS NOTED

PROJECT MANAGER:	RSC	PROJECT NO:	17123
A/E OF RECORD:	KDD		
JOB CAPTAIN:	SDL		
DRAWN BY:	CWF		
SMRT FILE:	FP102-17123	SHEET No.	FP102

©COPYRIGHT 2016 SMRT INC.

30x42