NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0224 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0224 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0218 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0388 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0389 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.

TOP OF WALL DETAILS (B1)

3" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/09/18

REV	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	12-21-17

ISSUED FOR CONSTRUCTION
12-21-17

CURRENT ISSUE STATUS:

LICENSED ARCHITECT REBECCA S. CASEY No. 2915 STATE OF MAINE 12 21 17

SMRT Architects and Engineers
144 Fore Street/P.O. Box 618
Portland, Maine 04104

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY

MAINE MEDICAL CENTER
M.M.C. HUTCHINS DRIVE
RENOVATION

PROJECT LOCATION

TOP OF WALL DETAILS

SHEET TITLE:

0" 1/4" 1/2" 1" 2" 3"

SCALE: AS NOTED

PROJECT MANAGER:	RSC	PROJECT NO:	17123
A/E OF RECORD:	RSC		
JOB CAPTAIN:	SDL		
DRAWN BY:	SDL/JMM		
SMRT FILE:	GI003-17123	SHEET No.	GI003

COPYRIGHT 2017 SMRT INC

30x42