


GLU LAM BEAM SCHEDULE	
MARK	SIZE
GLB-1	5 1/8x24 3/4
GLB-1A	5 1/8x28 7/8
GLB-2	5 1/8x13 3/4
GLB-3	6 3/4x24 3/4
GLB-3A	6 3/4x28 7/8
GLB-4	5 1/8x19 1/4
GLB-5	6 3/4x19 1/4
GLB-6	5 1/8x15 1/8
GLB-7	6 3/4x15 1/8

GLU LAM COLUMN SCHEDULE			
MARK	"b"	"h"	COMMENTS
C1	6 3/4"	6 7/8"	
C2	8 1/2"	8 1/4"	
C3	(2)x3 1/2"	6 7/8"	FLITCH PLATE COLUMN (SEE DWG S1.5)

NOTES:
 1. INDICATES ORIENTATION OF GLU LAM COLUMN W/RESPECT TO WIDE AND NARROW FACES (SEE TYP COLUMN ORIENTATION DETAIL DWG S1.6).



SECOND FLOOR FRAMING PLAN
 1/8"=1'-0"


- NOTES:
- INDICATES SPAN DIRECTION OF 7/8" T & G PLYWOOD FLOOR SHEATHING, GLUED AND SCREWED TO SUPPORTS. PLYWOOD SHEATHING SUPPORTS 1 1/2" GYPCRETE TOPPING (SEE ARCH).
 - TOP OF SLAB EL 12'-0" U.N.O. TOP OF SUBFLOOR EL 11'-10 1/2" U.N.O.
 - GLB-1, GLB-2, ETC. INDICATES GLU-LAM BEAM. SEE SCHEDULE THIS DWG. TOP OF GLULAM EL 11'-9 5/8" U.N.O. BY (±X'-X').
 - TOP OF STEEL EL 11'-8 1/8" U.N.O.
 - INDICATES 2x6 WOOD STUD BEARING WALL.
 - INDICATES PLYWOOD SHEATHED WOOD STUD SHEARWALL. SEE ELEVATION AND SCHEDULE DWG S3.4.
 - BF-1, BF-2, ETC. INDICATES BRACED FRAME. SEE BRACED FRAME ELEVATIONS DWG S1.5 FOR ADDL INFO.
 - H.D. INDICATES SIMPSON HOLDDOWN ANCHOR. SEE SHEARWALL SCHEDULE DWG S3.4.
 - TRUSS DESIGN: TC DL 25 PSF, BC DL 10 PSF, TC LL 80 PSF. DESIGN SHALL CONSIDER LONG TERM DEFLECTIONS DUE TO SUSTAINED DEAD LOAD (CREEP).
 - GC COORDINATE LOCATIONS OF ALL MEP UNITS WITH TRUSS DESIGNER.



75 York Street
 Portland, Maine 04101
 simonsarchitects.com
 207.772.4656



PROJECT NAME:
PATRONS OXFORD OFFICES
 97 TECHNOLOGY PARK DRIVE
 PORTLAND, MAINE 04102
 UNITED STATES OF AMERICA



THIS DRAWING IS THE PROPERTY OF SCOTT SIMONS ARCHITECTS (SSA) AND IS NOT TO BE COPIED OR REPRODUCED IN PART OR WHOLE
 2016 © SCOTT SIMONS ARCHITECTS, LLC

REVISION:	DATE
1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE

DATE OF ISSUE: 14 JANUARY 2016
 PROJECT NUMBER: 3565
 STATUS: CONSTRUCTION DOCUMENTS

SECOND FLOOR FRAMING PLAN

S1.2