

Ryan Kanteres
SSA Architects
75 York St
Portland, ME 04101

Derek Converse, LEED AP BD+C
Director of Preconstruction and Estimating
Zachau Construction Inc.
1185 US Route One // PO Box J // Freeport, ME 04032

March 15, 2016

Derek,

We have prepared the attached documents to respond to the concerns raised on the plan mark ups we received earlier, as well as to submit updates from client initiated addendum. Per the client's security request we have eliminated two exterior doors. These doors were previously utilized for supplemental egress, but we feel that the building is able to accommodate egress requirements without these doors.

We are including a fully updated G002 Life safety plan + Code summary, to address these changes and respond to comments about the calculated occupancy, exit access, and plumbing fixtures. While we have supplemented documentation our interpretation is still that the central stair opening is a permitted convenience opening rather than an atrium. We have also attached the requested ComCheck documentation, furniture plans, and supplemental information on the finishes.

As always feel free to contact me with any concerns or questions that you might have.

Best regards,
Ryan