

930377

Permit #            City of Portland BUILDING PERMIT APPLICATION Fee 25.00 Zone            Map #            Lot #           

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Dr. Susan Collett Phone #             
Address: 888 Brighton Ave Ptd 1d  
LOCATION OF CONSTRUCTION 888 Brighton Ave  
Contractor: Sentry Protective Systems  
536 Riverside St Ptd, ME 04103 Sub:             
Address:            Phone # 797-7799

Est. Construction Cost: 1,364.36 Proposed Use: Drs Office w/fire alarm Zoning:             
# of Existing Res. Units            # of New Res. Units            Past Use: Drs Office  
Building Dimensions L            W            Total Sq. Ft.             
# Stories:            # Bedrooms            Lot Size:             
Is Proposed Use: Seasonal            Condominium            Conversion             
Explain Conversion Install Fire Alarm System

**For Official Use Only**  
Date May 11, 1993 Subdivision:             
Inside Fire Limits            Name            Lot             
Bldg Code            Ownership:            Public            Private             
Time Limit            Estimated Cost           

Street Frontage Provided:            Back            Side             
Provided Setbacks: Front            Back            Side             
Review Required:             
Zoning Board Approval: Yes            No            Date:             
Planning Board Approval: Yes            No            Date:             
Conditional Use: Variance            Site Plan            Subdivision             
Shoreland Zoning Yes            No            Floodplain Yes            No             
Special Exception             
Other (Explain) WPA 5-11-93

**Ceiling:**  
1. Ceiling Joists Size:            Spacing             
2. Ceiling Strapping Size            Spacing             
3. Type Ceilings:            Size             
4. Insulation Type            Size             
5. Ceiling Height:           

**Roof:**  
1. Truss or Rafter Size            Span             
2. Sheathing Type            Size             
3. Roof Covering Type             
Chimneys: Type:            Number of Fire Places           

**Heating:** Type of Heat:             
**Electrical:** Service Entrance Size:            Smoke Detector Required Yes            No             
**Plumbing:** 1. Approval of soil test if required Yes            No             
2. No. of Tubs or Showers             
3. No. of Flushes             
4. No. of Lavatories             
5. No. of Other Fixtures           

**Swimming Pools:**  
1. Type:            Square Footage             
2. Pool Size:             
3. Must conform with            and State Law.

Permit Received By            Permit Issued             
Signature of Applicant            Date May 11, 1993  
Signature of CEO            Date             
Inspection Dates            White Tag - CEO             
White-Tax Assessor            Yellow-GPCOG           

**Foundation:**  
1. Type of Soil:             
2. Set Backs - Front            Rear            Side(s)             
3. Footings Size:             
4. Foundation Size:             
5. Other           

**Floor:**  
1. Sills Size:            Sills must be anchored.  
2. Girder Size:             
3. Lally Column Spacing:            Size:            Spacing 16" O.C.  
4. Joists Size:            Size:             
5. Bridging Type:            Size:             
6. Floor Sheathing Type:            Size:             
7. Other Material:           

**Exterior Walls:**  
1. Studding Size            Spacing             
2. No. windows             
3. No. Doors             
4. Header Sizes            Span(s)             
5. Bracing: Yes            No             
6. Corner Posts Size             
7. Insulation Type            Size             
8. Sheathing Type            Size             
9. Siding Type            Weather Exposure             
10. Masonry Materials             
11. Metal Materials           

**Interior Walls:**  
1. Studding Size            Spacing             
2. Header Sizes            Span(s)             
3. Wall Covering Type             
4. Fire Wall if required             
5. Other Materials           

**PERMIT ISSUED**  
**PERMIT RECEIVED BY**  
MAY 11 1993  
MICHAELE STURGIS

PLOT PLAN



*Don't list any*

FEES (Breakdown From Front)

Base Fee \$ \_\_\_\_\_

Subdivision Fee \$ \_\_\_\_\_

Site Plan Review Fee \$ \_\_\_\_\_

Other Fees \$ \_\_\_\_\_

(Explain) \_\_\_\_\_

Late Fee \$ \_\_\_\_\_

Type

Inspection Record

Type	Inspection Record	Date
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____
_____	_____	_____ / _____ / _____

COMMENTS

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Signature of Applicant Michael Avers Date 5/11/93

BUILDING PERMIT REPORT

Date: 5/12/93  
Address: 888 Brighton Ave  
Reason for Permit Install Fire Alarm System

Building Owner: Dr. Susan Collett  
Contractor: Sentry Protective  
Permit Applicant: Michelle Sturges  
Approved:  Denied:

Conditions of Approval or Denial:

1. All required Fire Alarm systems shall have the capability of "Zone Disconnect" via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
2. All remote annunciators shall have a visible "trouble" indicator along with the Fire Alarm "Zone" indicators.
3. ~~Any Master Box connected to the Municipal Fire Alarm System shall have a supervised Municipal Disconnect Switch.~~
4. ~~All Master Box locations shall be approved by the Fire Department Director of Communications. A Master Box shall be located so that the center of the box is (5') five feet above finished floor.~~
5. ~~All Master Box locations are required to have a locked box (knoxbox)~~
6. A fire alarm acceptance report shall be submitted to the portland Fire Department