

DAILY SUMMARY REPORT

Report Number: J3091112.0006
Service Date: 02/01/10
Report Date: 02/04/10
Task:

Terracon

15 Holly St.
Scarborough, ME 04074
207-396-5374

Client

BKA Architects
Attn: Matt Pelletier
142 Crescent Street
Brockton, MA 02302

Project

W.B. Mason Expansion
106 Pine Tree Industrial Parkway
Portland, ME 04102

Project No. J3091112

A Terracon representative visited the above-referenced site to provide construction monitoring services limited to excavation observation and subgrade preparation.

Earthwork activities (subgrade preparation) were in general accordance with project specifications.

Locations of today's project activities are illustrated on the attached Field Sketch.


Please refer to the attached report no(s). 0006A, 0006B for further information.

Weather during today's activities was clear, 20's F

Lunch/Nonchargeable:

Report Distribution

(1) BKA Architects

Reviewed by 
Wendell Shedd

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

EXCAVATION OBSERVATION REPORT

Terracon

15 Holly St.
Scarborough, ME 04074
207-396-5374

Report Number: J3091112.0006A
Service Date: 02/01/10
Report Date: 02/04/10
Task:

Client

BKA Architects
Attn: Matt Pelletier
142 Crescent Street
Brockton, MA 02302

Project

W.B. Mason Expansion
106 Pine Tree Industrial Parkway
Portland, ME 04102

Project No. J3091112

Services Requested By: Skip Schofield, Turner Brothers, LLC

Observation Location(s): Along line E between 17.5 and 18, along 18 between E and J

Excavated Material Description: Existing fill

Exposed Subgrade Review: The exposed subgrade consisted of clay and was observed to be firm and stable.

Summary: Based on our observations, excavation activities at the above-referenced locations appeared to have been completed in general accordance with the project plans and specifications. Results were reported to Skip Schofield at the completion of today's activities.

Additional Comments:

Terracon Rep: Ethan M. Marro
Contractor: Turner Brothers, LLC

Lunch/Nonchargeable:

Report Distribution

(1) BKA Architects

Reviewed by


Wendell Shedd

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

SUBGRADE PREPARATION REPORT



15 Holly St.
Scarborough, ME 04074
207-396-5374

Report Number: J3091112.0006B
Service Date: 02/01/10
Report Date: 02/04/10
Task:

Client

BKA Architects
Attn: Matt Pelletier
142 Crescent Street
Brockton, MA 02302

Project

W.B. Mason Expansion
106 Pine Tree Industrial Parkway
Portland, ME 04102

Project No. J3091112

Services Requested By: Skip Schofield, Turner Brothers, LLC
Foundation Type: Continuous footing
Observed Location(s): Along column line E between 17.8 and 18, along column line 18 between E and J
Subgrade Description: 2-4 feet of stone over geotextile fabric over existing clay

Summary: The foundation subgrade appeared firm and stable. Based on our observations, the foundation subgrade preparation at the above-referenced locations appeared to be in general accordance with project specifications. Results were reported to Skip Schofield at the completion of todays activities.

Additional Comments: Subgrade was over excavated 2-4 feet to remove saturated native clays. The contractor then layed down a woven geotextile fabric and 2-4 feet of crushed stone to bottom of footing elevation.

Terracon Rep: Ethan M. Marro
Contractor: Turner Brothers, LLC

Lunch/Nonchargeable:

Report Distribution
(1) BKA Architects

Reviewed by 
Wendell Shedd

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

