

DAILY SUMMARY REPORT

Report Number: J3091112.0001
Service Date: 01/21/10
Report Date: 01/25/10
Task:

Terracon

15 Holly St.
Scarborough, ME 04074
207-396-5374

Client

BKA Architects
Attn: Matt Pelletier
142 Crescent Street
Brockton, MA 02302

Project

W.B. Mason Expansion
106 Pine Tree Industrial Parkway
Portland, ME 04102

Project No. J3091112

A Terracon representative visited the above-referenced site to provide construction monitoring services limited to reinforcing steel observation.

Locations of today's project activities are illustrated on the attached Field Sketch.

Please refer to the attached report no(s). 0001A for further information.

Weather during today's activities was clear, 20's

Lunch/Nonchargeable:

Report Distribution

(1) BKA Architects

Reviewed by



Wendell Shedd

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

REINFORCING STEEL OBSERVATIONS REPORT

Terracon

15 Holly St.
Scarborough, ME 04074
207-396-5374

Report Number: J3091112.0001A
Service Date: 01/21/10
Report Date: 01/25/10
Task:

Client

BKA Architects
Attn: Matt Pelletier
142 Crescent Street
Brockton, MA 02302

Project

W.B. Mason Expansion
106 Pine Tree Industrial Parkway
Portland, ME 04102

Project No. J3091112

Services Requested By: Turner Construction
Construction Type: Cast-in-place concrete
Observation Location(s): Expanded and new interior footings between column lines A and D, 7 and 4.5

Summary: Based on our observations, the reinforcing steel placement at the above-referenced locations appeared to be in general accordance with the project drawings identified below. Results were reported to Turner Construction at the completion of today's activities.

Referenced Drawing(s): S2, S5

Additional Comments: Where footings were enlarged, reinforcing steel dowels were drilled and epoxied using Hilti HIT-HY 150 max.


Terracon Rep: Ethan M. Marro
Contractor: Turner Construction

Lunch/Nonchargeable:

Report Distribution

(1) BKA Architects

Reviewed by



Wendell Shedd

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

